



STATE OF WISCONSIN

Department of Safety and
Professional Services

Approval # 20110006

Environmental & Regulatory Services Division
Bureau of Petroleum Products and Tanks
201 West Washington Avenue
P.O. Box 7837
Madison, WI 53707-7837

Wisconsin SPS 310 Material Approval

Equipment: MassTech 2 Wet Volumetric and MassTech
002 Ullage Non-volumetric Tank Tightness
Tests

Manufacturer: MassTech International, Ltd.
as Licensed to:
Leighton O'Brien USA, Inc.
5135 Centennial Boulevard
Colorado Springs, CO 80919

Expiration of Approval: December 31, 2014

SCOPE OF EVALUATION

The MassTech 2 Wet Volumetric and the MassTech 002 Ullage Non-volumetric Tank Tightness Tests, manufactured by MassTech International, Ltd. have been evaluated in accordance with **s. SPS 10.130(1)(a)** of the current edition of the Wisconsin Administrative Flammable and Combustible Liquids Code.

This evaluation summary is condensed to provide the specific installation, application and operational parameters necessary to maintain the subject systems in compliance with the Wisconsin Administrative Code – SPS 310.

DESCRIPTION AND USE

The MassTech tank tightness testing system consists of two separate components; the wet test and the ullage test. The wet test component tests only the liquid filled portion of the tank, the ullage test component tests only the non-liquid portion of the tank; combining both tests would test the whole tank. The ullage test can be used for precision tightness testing a completely empty tank.

MassTech 2 Wet Test Method

The MassTech 2 Wet Test Method is based on measurement of the liquid mass in an underground tank using a pressure sensor located at the bottom of the tank. The technology relies on hydrodynamic principles, which essentially negates temperature effects. The floor of the tank is used as the reference point for all measurements. During the leak test data acquisition phase the position of the sensor must not move as all readings are taken relative to the bottom location. The sensor may be inserted into the tank at any suitable opening in the tank top, including the fill pipe as long as the sensor is in a position where the weight of the fuel in the body of the tank impacts on it.

The electronic sensor is connected to a probe by a narrow tube carrying low pressure nitrogen and is monitored externally to the tank with results collected using a computer. Data collected is electronically transmitted to a data collection center for analysis. All mass readings are taken with the tank open to atmosphere; the system measures a quantity equivalent to the mass of liquid in the tank at atmospheric pressure during the course of a test. If suitable conditions exist, the method may be combined with a pressure ullage test to complete testing of the entire tank. If no ullage pressure test is required or possible, mass measurements are collected at the start and finish of the test period.

Since the difference in mass between the start and finish of the test, combined with the time between these events defines the apparent rate of change of mass, the system can detect ingress as well as egress of any liquid (water or fuel) that might be in the backfill surrounding the tank. This principle allows the system to test for any liquid ingress including water ingress. If the ingressed liquid is not water, the system will understate or overstate volumes gained in proportion to the density difference, though the mass of the ingress will not change.

The sensitivity of the system to changes of mass is lowest where the surface area is at a maximum. The certification tests contained within the certification document show that with a surface area of 355 ft², a change rate as low as 0.027gph can be detected within 30 minutes. Proportionately, smaller surface areas and larger leak rates can be detected. Mass readings are usually duplicated at each point in time to allow invalid readings to be eliminated without requiring a retest. Where ingress is suspected a second wet test is normally carried out back to back with the first but with under different conditions. The second test is typically conducted with an ullage pressure increase or reduction between the two sets of mass readings. By this means the rate of loss or gain of the tank can be compared under different conditions avoiding problems with possible pressure imbalances between the inside and the outside of the tank shell. The two back to back tests may also allow for diagnostic and leak location possibilities.

MassTech 002 Ullage test Method

The MassTech 002 Ullage test system can be used in one of several modes: 1) Monitoring absolute pressure changes (either positive pressure or vacuum) or 2) acoustic signals with computer generated results (either positive pressure or vacuum) or 3) a combination of the two. The tank pressure is adjusted to approximately 1.5 psig above or below the ambient pressure conditions and pressure changes are monitored. A computer is used to log the data usually at 10-second intervals. This data is remotely analyzed and is therefore normally forwarded electronically to an analysis center where trained staff uses proprietary software to assist in the determination of the tank condition.

To conduct a test, all of the openings in the tank such as bungs, risers, manways, etc., shall be sealed completely. This is accomplished by pressurizing the tank and soaping all visible fixtures along the top of the tank. Any leaks here will adversely affect the test results and may cause a false alarm. The test equipment must be installed, including the pressure sensors, as well as a means to produce vacuum or pressure on the ullage of the tank. While the on-site test technicians may have some indication of the condition of the tank, the final call is made by the analysis center.

Testing is conducted in three stages. The first stage involves monitoring the sealed tank under ambient conditions (25-minute stabilization). The sealed tank is monitored for pressure changes without any initial pressure or vacuum on the tank. This data is used to correct the test results for background effects such as pressure changes due to temperature or volatility of the product in the tank.

The second stage of the test is the pressure portion, with the pressure adjusted to the test conditions, usually a pressure difference of around +1 to -1.5 psig, using nitrogen pressure or a vacuum pump.

The third stage is the data collection, typically lasting 20 minutes of which the last five are considered of critical importance for declaring a result.

TESTS AND RESULTS

The performance of the MassTech 2 Wet Test as an annual tank tightness testing method was verified by Ken Wilcox Associates in accordance with the EPA Protocol for volumetric tank tightness testing systems. The MassTech 2 Wet Test system was found to detect a leak of 0.1 gph with 100 percent probability of detection and 0% percent probability of false alarm. The calculated confidence interval was within established parameters; this illustrates that the data set was large enough to provide a realistic assessment of the expected detection and false alarm capabilities.

The performance of the MassTech 002 Ullage Test as an annual tank tightness testing method was verified by Ken Wilcox Associates in accordance with the EPA Protocol for non-volumetric tank tightness testing systems. The MassTech 002 Ullage Test system was found to detect a leak of 0.1 gph with 100 percent probability of detection and 0% percent probability of false alarm. The calculated confidence interval was within established parameters; this illustrates

that the data set was large enough to provide a realistic assessment of the expected detection and false alarm capabilities.

LIMITATIONS / CONDITIONS OF APPROVAL

- Data is collected and reviewed for accuracy by technician on-site; however, result declaration and certification can only be determined by remote analysis using MassTech proprietary software.
- When using acoustic listening devices, testing must be conducted under reasonably quiet conditions. Heavy traffic, nearby trains, industrial centers, or construction activities could produce sound levels that could compromise the test. Testing periods should be selected in order to minimize these effects.
- Atmospheric conditions shall be stable and not subject to violent change during data collection process.
- All operators of the MassTech tank tightness testing methods shall pass certification testing through MassTech International, Ltd., and be re-certified every two years to maintain their certification.
- Equipment shall be calibrated on an annual basis by MassTech International, Ltd., and documented by serial number. The Certificate of Calibration shall be provided with the submittal of any test forms to the department.
- A sample MassTech UPSS Test report is provided in Appendix A of this approval.

MassTech 2 Wet Test Method:

- The MassTech 2 Wet Test is approved for use as a method of tank tightness testing for the liquid containing portion of the tank as specified in **s. Comm 310.510(3)**.
- This method can be used to test tanks with gasoline, diesel, aviation fuel, #4 fuel oil, waste oil, and other liquids with manufacturer approval.
- **If the groundwater level is above the tank bottom, or if depth to groundwater is not determined, then the MassTech 2 Wet Test shall consist of two separate tests with a minimum of a nominal 1.5 psi pressure differential in the ullage between the two tests.**
- Critical performance parameters for the MassTech 2 Wet Test Method:

| Parameter | Value |
|---|----------------------|
| Tank size for a single tank | Up to 30,000 gallons |
| Minimum allowable product level | 5 % of tank volume |
| Average waiting time after filling tank | 15 Minutes |
| Maximum allowable temperature difference between product in the tank and product delivered just prior to running a test | ± 9.9 deg F |
| Average Data Collection Time per Test | 30 Minutes |

MassTech 002 Ullage Test:

- The MassTech 002 Ullage Test is approved for use as a method of tank tightness testing for the ullage space only as specified in **s. Comm 10.510(3)**.
- This method can be used to test tanks with gasoline, diesel, aviation fuel, #4 fuel oil, waste oil, and other liquids with manufacturer approval. Tank can be empty or contain up to 95% liquid by volume. If tank contains liquid then a separate wet test shall be performed to confirm tightness of the whole tank.
- **Prior to beginning any testing, groundwater level must be determined by measurement through the use of an observation well or soil probe in the tank excavation backfill.**
- **If groundwater is above tank bottom, a water sensor shall be located at the bottom of the tank or the test shall be conducted in conjunction with the standard MassTech Wet Test.**
- Vacuum test method may not be effective in some tank backfills due to clay plugging the tank hole or free product in the tank backfill. Conversely, pressure tests may not be effective in all cases due to the possibility of a crack closing under test pressure. If a leaking tank is suspected then both a vacuum and pressure test may be appropriate.

- Critical performance parameters for the MassTech 002 Ullage Test Method:

| Parameter | Value |
|--|--|
| Tank size for a single tank | Up to 30,000 gallons |
| Minimum allowable ullage volume | greater than 5 % |
| Nominal test vacuum or pressure | 1.5 psi |
| Average waiting time after filling tank | 2.38 hrs. with tank filled to 5% 1.5 hrs. with tank filled to 50% 0.27 hrs. with tank filled to 95% |
| Total Data Collection Time per Test ¹ | 2.63 hrs. with tank filled to 5% 1.75 hrs. with tank filled to 50% 0.52 hrs. with tank filled to 95% |

1: 25-minute static test may be shortened by the technician when steady-state conditions are reached earlier.

This approval will be valid through December 31, 2014, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department. The Wisconsin Material Approval Number must be provided when plans that include this product are submitted for review.

DISCLAIMER

The Department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement unless specified in this document.

Effective Date: June 1, 2011

Reviewed by: Signature on file
 Greg Bareta, P. E.
 Engineering Consultant
 Bureau of Petroleum Products and Tanks

Approved by: Signature on file Date: _____

APPENDIX A: Sample Report

UPSS Test Report

June 30, 2011

Marathon
24820 75th St.
, WI

Test Date: June 20, 2011
Reason for Test: Due Diligence
Service Distributor: Petroleum Svcs.



LEIGHTON O'BRIEN INC
Tank Integrity Solutions

Leighton O'Brien Inc
2812 Janitell Road
Colorado Springs, CO 80906
Telephone: (719) 576-9816
Toll Free: (866) 488-2657
Fax: (719) 576-0170
E-mail: jeffstevenson@leightnobrien.com
Website: www.leightnobrien.com

Executive Summary

The Regular & Premium tanks & lines passed the tests.

There are no recommendations.



Aim

To investigate the integrity of the UPSSs as a due diligence exercise.

Method

The tanks and all their associated tank top components (i.e. vent, fill, ATG) were subjected to the MassTech tank test.

Individual tests were performed on the product lines.

Summary of Tank Results as Tested

| Test Round 1 | | | |
|---|-------------------|------------|------|
| Tank | Test | Result | Rate |
| Regular Tank 1 (10000 Gal.) at 0 gal or 0 % fill (& 0 in. H2O) Jun 15 2011 Cert. No. 144086 | Wet Static Test | not tested | |
| | Wet Pressure Test | not tested | |
| | Ullage Test | PASS | |
| Premium Tank 2 (10000 Gal.) at 0 gal or 0 % fill (& 0 in. H2O) Jun 20 2011 Cert. No. 144091 | Wet Static Test | not tested | |
| | Wet Pressure Test | not tested | |
| | Ullage Test | PASS | |

Nomenclature for tables above

- A 6.5 times ullage fail is the nitrogen decay equivalent to a liquid leak under 1.45 PSI at the USEPA threshold of 0.1 gal/hr
- 0.1 gal/hr is the PASS/FAIL criteria for a USEPA precision test.
- MassTech technology used: Masstech 2 wet test (mass based) and Masstech 002 ullage test (pressure). For further details go to www.nwglde.org/vendor_indexG_M.html
- (i) indicates a liquid ingress was detected during the test at the noted rate
- (e) indicates a liquid egress was detected during the test at the noted rate

Summary of Line Results as Tested

| Line Test Round 1 | | |
|-------------------|-----------|--------|
| Description | Date | Result |
| Regular | 20-Jun-11 | PASS |
| Premium | 20-Jun-11 | PASS |

Leighton O'Brien PM2 test equipment & procedure used

Other Relevant Observations

- All visible parts of the systems, sealed by the technician, were shown to be tight using soapy water.

Comments/Discussions

The Regular & Premium tanks & lines passed the tests.

Recommendations

There are no recommendations.

Addendum

Date of Test: June 20, 2011
 Licensed MassTech Tester: Casey Mangrum
 Report Prepared by: Jeff Stevenson
 Report ID:

Diagnostic Report to 20-Jun-11.doc

Glossary of Acronyms used

UPSS Underground Petroleum Storage System
 USEPA United States Environmental Protection Agency

The underground pipe and tank configurations contained in this report are deduced from information gathered at the site by Leighton O'Brien and by information given to Leighton O'Brien by the client.

Details of Line Test

| Regular | | | | |
|----------|-----------|----------|-------|--------|
| Line | PASS | Time | psi | gal/hr |
| Valve | NA | 10:35:37 | 48.59 | 0.003 |
| Tested | Wet | | | |
| Start | 10:30:00 | | | |
| Date | 20-Jun-11 | | | |
| Unit SN | | | | |
| Cert No. | 242 | | | |


| Premium | | | | |
|----------|-----------|----------|-------|--------|
| Line | PASS | Time | psi | gal/hr |
| Valve | NA | 11:26:15 | 48.61 | -0.025 |
| Tested | Wet | | | |
| Start | 11:20:37 | | | |
| Date | 20-Jun-11 | | | |
| Unit SN | | | | |
| Cert No. | 243 | | | |

MassTech Tank Test Report


Dry **PASS**

Facility Details
 Marathon
 24820 75th St. WI

Regular Tank 1



| Mass Test | Time | Units |
|------------------|-----------------------|---------|
| No Mass Readings | | |
| Ullage Test | Time | psi |
| Initial Value | 10:55:35 | 15.6597 |
| Test 1 Value | 11:25:45 | 15.5911 |
| Test 2 Value | 11:30:45 | 15.5678 |
| | dP/dT (psi/5min) | -0.0033 |
| | Pass limit (psi/5min) | -0.0039 |





MassTech Tank Test Report

Dry **PASS**
Facility Details
 Marathon
 24820 75th St.
 WI

Premium Tank 2


| Mass Test | Time | Units |
|------------------|-----------------------|---------|
| No Mass Readings | | |
| Ullage Test | Time | psi |
| Initial Value | 11:14:46 | 15.6647 |
| Test 1 Value | 12:31:45 | 15.5248 |
| Test 2 Value | 12:36:45 | 15.5193 |
| | dP/dT (psi/5min) | -0.0055 |
| | Pass limit (psi/5min) | -0.0055 |



LEGEND

- Point Sealed for Ullage Test
- Nitrogen Injection Point
- Submersible Pump Head

Site Diagram



Not to Scale