



---

## Chapter SPS 323

### Subchapter I — Scope

### Subchapter II — Design

#### 323.02 Sizing of Heating Equipment

Note that the outdoor air design temperatures for heat loss calculations shall be taken from the figure in the UDC Appendix. Indoor design temperature is established in s. SPS 322.40 as being 70 degrees for heated areas.

Previously, the federal energy code compliance software, Rescheck, included a Wisconsin-specific option to size the dwelling heating plant. However the newest software version available on the federal DOE website no longer has the option to calculate heating plant sizing. In order to continue to offer that service, the older version of REScheck, build version **4.6.2.0**, is on the Wisconsin UDC Links webpage for downloading. (This may be confirmed by looking at “About” under “Help” on the menu bar of the software. Note that you may have problems if you have more than one version of REScheck on your computer). If you use this version, you must first calculate building envelope compliance by selecting the “**2009 IECC**” under “Code” on the menu bar, even though you may see a warning that your location requires use of the “**Wisconsin 2009**” code. After printing that out and without exiting REScheck, you may switch your code to “Wisconsin 2009”, enter your county location and calculate your heating plant size on the Loads tab, as before.

Alternatively to size your heating plant by hand calculation after you have calculated building envelope compliance per the 2009 IECC, you would perform the following calculations, ignoring the units of measure:

1. Multiply the value in the “Your UA” field, from the Envelope tab of Rescheck, by the temperature difference for your dwelling location, which is 70 minus the value from the Outdoor Design Temperature of SPS 323.02(1) table and map in Appendix A of the UDC. (Note that subtracting a minus value is the same as adding.)
2. Calculate your conditioned building volume by multiplying your total conditioned floor area including basements in square feet by its average ceiling height in feet.
3. Select an air infiltration rate between 0.2 and 0.5 air changes per hour, based on your estimated dwelling envelope tightness.
4. Multiply the building volume value from step 2 by your selected air infiltration rate from step 3 and by your temperature difference and by the constant 0.018.
5. Add together the values from steps 1 and 4 to obtain your minimum heating plant output capacity, in BTU/hour. (Note that the UDC no longer has an over-sizing limit.)

323.02(3)(a) Exhaust Fan Termination

**Question:** Can an exhaust fan terminate inside a garage, crawlspace or attic near a vent?

**Answer:** No. It must have an **exterior termination**. The air currents may otherwise draw the exhaust back into the space. It is recommended that where exhaust terminates in the soffit space of an overhang, the soffit should be “blanked-off” for a 2’ distance on either side of that vent termination.

323.02(3)(b) Balancing of HVAC Equipment

**Question:** What does "balanced" mean?

**Answer:** It means that the ventilation system should not produce excessive positive or negative pressures in the dwelling. Excessive negative pressure can cause chimney or vent back-drafting of combustion products or even carbon monoxide poisoning. Commentary for SPS 322 deals with leaking of buildings and the moisture that moves into or out of a dwelling - see those comments for related balance issues.

323.02(3)(b)2. Outside Air Intake Sizing

**Question:** How do I size the outside air intake to balance my dwelling's exhaust?

**Answer:** The minimum amount of make-up air must be 40% of the total exhaust. Size the duct considering the minimum and maximum flowrate conditions specified in s. SPS Table 323.07, Duct Velocities. Per this table, the minimum duct velocity is 500 ft/min and maximum allowable is 800 ft/min for outside air intakes.

Example: **Determine size of make-up air duct required for these exhaust systems.**

Range hood	=	180 cfm (intermittent)	x	40%	=	72 cfm
Bath exhaust 1	=	50 cfm (intermittent)	x	40%	=	20 cfm
Bath exhaust 2	=	75 cfm (intermittent)	x	40%	=	30 cfm
<b>TOTAL</b>		<b>305 cfm (intermittent)</b>	<b>x</b>	<b>40%</b>	<b>=</b>	<b>122 cfm</b>

Based on the formula of Quantity = Velocity times Area (Q=VA). THEREFORE:...

Check Minimum Duct Size (& max. duct velocity) of  $A=Q/V$ , or  $A=122/800$ , or  $A=0.1525$  sq. ft. x 144 = 21.96 sq. in. (required)

Try 4” round duct = 3.14 x radius squared = 3.14x2x2 = 12.56 sq. in. (too small)

Try 6” round duct = 3.14 x radius squared = 3.14x3x3 = 28.26 sq. in. (OK since >21.96 in<sup>2</sup>)

Check maximum duct size (& min. duct velocity)  $A = 122/500 = .244$  x 144 = 35.136 sq. in. (therefore 6" round duct is OK since it is smaller than this)

Not doing the calculation described above to appropriately size the air intake may result in an oversized intake and cause the problems noted in s. SPS 323.07. The HVAC system shall be tested by the installer per SPS 323.18 to make sure the design amounts of air are actually provided when the system operates.

323.02(3)(d) Bathroom and Toilet Room Exhaust

The code requires that any bathroom or toilet room to have at least 50 cfm of actual exhaust provided. (Note that this size is smaller than what is recommended for rooms of over 50 square feet.) This means that if excessive ducting is installed on a 50 cfm exhaust fan, or even larger, the actual provided exhaust from the room may be less than 50 cfm. Fan installation manuals may have details on the allowable ducting, including diameter, material, length, elbows or bends and termination cap types. These need to be followed, especially if the fan is only rated 50 cfm or slightly larger. Some installation manuals are vague about allowable ducting, so the following guidance is provided to determine minimum duct design:

You need to calculate the equivalent duct length based on the duct construction, number of elbows or bends and the terminal. The basic rules that apply to both 3" and 4" duct, are as follows.

1. Measure the length of straight duct.
2. If the duct is flexible aluminum, multiply the length by 1.25.
3. OR If the duct is flexible insulated, multiply by 1.5.
4. For each elbow, add 15 feet.
5. For each terminal (wall cap, roof jack), add 30 feet.

If your equivalent length exceeds 100', then a 50 cfm fan is not adequate.

Note that SPS 322.39(5) requires a damper on exhaust ducts.

### **Subchapter III — Heating Equipment**

#### 323.03 Selection of Equipment

See s. SPS 323.02 regarding sizing of heating equipment.

#### 323.04 Listing of Equipment

All heating equipment including woodstoves and decorative gas appliances (gas fireplaces) must be listed by a recognized testing agency. An important part of inspecting an appliance's installation is to check against its listed installation requirements. Therefore, it is good practice to refer to the installation manual when installing and inspecting the installation. Per s. SPS 323.18(1), an appliance's manual is required to be left with the owner. Per s. SPS 320.09, it can be required for plan review or inspection by the inspector.

#### 323.04(2)(b) Unvented Furnaces and Space Heaters and Fireplaces

Portable kerosene and other types of unvented heaters are being advertised and sold in Wisconsin. However, neither the Commercial Building Code nor the Uniform Dwelling Code permits their use, even if provided with oxygen depletion sensors. Use of such heaters is prohibited because the heaters are not vented and can cause a buildup of carbon monoxide and

#### 323.04(4)

moisture in the room. Further, the heaters require frequent refueling which can lead to spillage and additional fire hazard.

**Question:** If unvented heaters are prohibited by the UDC and the Commercial Building Code, why are kerosene, natural gas, and alcohol fueled heaters still being sold?

**Answer:** These heaters are not necessarily illegal in structures not covered by either code, such as pre-1980 dwellings or agricultural buildings. However, some municipalities have adopted ordinances prohibiting unvented heaters in pre-1980 dwellings or other buildings.

**Question:** Can an unvented heater be used in a residential garage?

**Answer:** Only in detached garages, since the UDC SPS 320.07 (35) defines an attached garage as part of the dwelling. Therefore, the attached garage would have to comply with all chapters of the UDC. Most municipalities have their own ordinances of codes covering construction of accessory buildings, such as detached garages.

#### 323.04(4) Solid Fuel-Fired Water Heating Appliances

The water in solid fuel-fired heating appliances shall **not** be at any pressure above atmospheric pressure. If it is pressurized, the appliance shall meet all applicable Boiler Code requirements.

#### 323.04(5) Dual Use Water Heaters

See the checklist at the end of this chapter for code issues relative to water heaters used for potable and space heating purposes.

#### 323.04(6) Location

**Question:** How do I determine if a furnace is listed for installation in a bedroom, bathroom, closet or garage?

**Answer:** Although this information may not be shown on the unit, it does need to be covered in the installation instructions which must be provided to the owner, per s. SPS 323.18. Many times these installation instructions reference NFPA-54, National Fuel Gas Code for garage installation procedures.

**Question:** Since this section limits location of furnaces in a garage, can a wood stove or other space heater be located in a garage?

**Answer:** Not unless listed for such use. See s. SPS 323.045(2)(b).

**Question:** Can a furnace be located in an attic?

**Answer:** Yes, if within the manufacturer's listing requirements. The following UDC requirements and typical manufacturer's requirements would usually apply:

- Provide attic access opening large enough for the appliance.
- Provide combustion air per s. SPS 323.06.
- Maintain manufacturer's and UDC clearances to combustibles and clearances for servicing.

- Provide lighting for servicing the appliance.
- Provide a solid walkway to the appliance and solid platform under and around the appliance for servicing.
- Provide attic framing that will adequately support the furnace and servicing loads.
- Isolate the appliance from any loose insulation that could enter the combustion chamber.
- Isolate the appliance from any drafts caused by power attic venting of the attic.
- Use a non-condensing furnace since freezing temperatures would adversely affect a condensing-type furnace.

Also note that per SPS 322.42 and 322.43, the attic ductwork would need to be insulated, sealed and tested for air tightness.

Since the time that the UDC added a minimum burner elevation of 18” above a garage floor, flammable vapor ignition resistant (FVIR) gas appliances have become available that may be safely located in garages with their burners less than 18” above the floor. Based on SPS 323.04(1)(b), these appliances may be installed at less than 18” above a garage floor if their listing allows it.

#### 323.045 Solid-Fuel-Burning Appliances

Effective February 1, 1989, solid-fuel-burning appliances had to be tested, listed and labeled by an accepted testing agency. (See s. SPS 321.32 commentary for approved agencies.)

At the time the Dwelling Code was first written (1980), nationally recognized standards on solid-fuel-type appliances were not available. Since that time, Underwriters' Laboratories have developed standards for testing and listing solid-fuel- burning appliances. Most models on the market are now tested, listed and labeled by approved independent agencies. When a specific installation instruction approved by the testing/listing agency is more or less stringent than s. SPS 323.045, then the listing agencies instructions govern.

#### 323.045(3)(b) Co-venting of Solid-Fuel Appliances

Note that this section does not allow co-venting of solid-fuel appliances. Each fireplace, woodstove, or other solid-fuel appliance must be vented to its own flue.

#### 323.045(4) Chimney Connectors

**Question:** Does a solid fuel appliance in front of an existing fireplace opening require a chimney connector?

**Answer:** Usually, for proper operation, a smokepipe is needed from the appliance outlet to the opening of the actual chimney flue per its listing. Additionally, a factory-built fireplace's listing must be compatible for such an alteration.

#### 323.045(6) Appliance Clearances

The requirement for proper clearances in this section refers to clearances to combustibles. It should be remembered that an appliance still needs to comply with s. SPS 323.045(2) for the proper servicing clearances.

A wood-frame wall with gypsum board or plaster finish is still considered a combustible wall for determining appliance and smokepipe clearances. Heat is readily conducted to the studs underlying the gypsum board. Over a period of time, the ignition temperature of the wood decreases as it is dried out and chemically changed. Noncombustible surface protection is only effective if there is at least a 1-inch air space between it and the combustible construction.

### 323.045(10) Combination Appliances

Note that this section requires combination appliances or dual-fuel appliances to be listed for the combination use. If allowed by the listing, the units may be vented by the same flue.

Table 323.045-C specifies the floor mounts for solid-fuel-burning appliances.

### 323.06 Combustion Air for Wood Stoves

**Question:** SPS 323.06(2). How do I calculate if a wood stove needs outside combustion air because of small room size?

**Answer:** If the appliance is listed, then an hourly input rating is given and the calculation is straightforward. An unlisted appliance's hourly input BTU rating can be figured on the following basis:

BTU input /hour = C x 60% (% firebox fill) x 40 lbs. wood/cubic foot x 8600 BTU/2 hours x  
1 fireboxfull = 103,200 BTU/HR/cubic foot x C

where: C = firebox capacity (cu. ft.) = l x w x h  
= product of inside firebox dimensions in feet.

### 323.06 Combustion Air

The code offers several methods to supply adequate combustion air. Below is a highlighted listing of the options. Also see the optional Makeup and Combustion Air Worksheet at the end of this chapter.

**Method 1. Inside Air (Discontinuous Vapor Retarder)** [323.06(3)]: Allows combustion air to be drawn from an inside space if the building has a discontinuous vapor barrier, as is permitted at boxesills or below grade walls by s. 322.38(2)(c). The space shall provide a room volume of at least 50 cubic feet per 1000 btu/hr combined input rating of all open combustion appliances in that space. An inside space may include several rooms if connected with high and low openings, with each opening providing one square inch of clear opening per 1000 btu/hr input rating, but not less than 100 square inches each.

**Method 2. Inside & Outdoor Air (Continuous Vapor Retarder)** [323.06(4)(d)]: If a building has a continuous vapor barrier, and therefore cannot use the method of 323.06(3) of taking all air from inside, but does have a room volume of at least 50 cubic feet per 1000 btu/hr combined input rating of all open combustion appliances in that space, then it can use a method of

supplementing the inside air with outside air. It shall be via a single, direct or ducted, exterior, high opening, sized at one square inch per 5,000 btu/hr combined input rating.

**Method 3. Single Outdoor Opening (Gas Appliances Only)** [323.06(4)(c)]: If serving only gas appliances, then from outdoors via a single, direct or ducted, exterior, high opening sized at one square inch per 3,000 btu/hr combined input rating, but not less than the combined cross sectional areas of the appliance flue collars or draft hood outlets in that space.

**Method 4. Prorated Inside Air Credit Plus Outdoor Air** [323.06(2)(d)]: For method 1, per current national standards [2006 NFPA 54-9.3.4], we will also allow a combination of drawing inside and outside combustion air, unless prohibited by the appliance manufacturer. This is done by taking a pro-rated credit for an inside space that partially meets method 1, and then making up the difference by pro-rating the outside combustion air otherwise required by Method 5 [323.06(4)(c)]. Example: If the inside space provides only 25 cubic feet per 1,000 btus, or half of the size required by method 1, then the additional direct or ducted outside combustion air, as calculated by method 5 can be reduced by one half.

**Method 5. Two Outdoor Openings** [323.06(4)(b)]: From outdoors via high and low direct or vertically ducted exterior openings, each sized at one square inch per 4,000 btu/hr combined input rating or via horizontally ducted openings, each sized at one square inch per 2,000 btu/hr combined input rating.

EXAMPLE:

1. Determine if the space in which the heating appliances are located is large enough to supply combustion air by itself per Method 1 pers. SPS 323.06(3).
  - a. The plans indicate a utility room will be constructed which houses a:
    - (1) Gas-fired furnace (100,000 BTU input).
    - (2) Gas-fired water heater (33,000 BTU input).

- b. The utility room size is approximately 12 ft. long by 5.5 ft. wide. This is 66 sq. ft. in area. The rest of the basement is 934 sq ft. in area.

The "Typical Section" drawing shows the room height to be 7 ft. 6 in. plus the depth of the floor joists 9 1/4 in. Therefore, the height then becomes 8.27 ft. The section also indicates that the vapor retarder is omitted on the boxesill, so s. SPS 323.06(3) may be used.

The volume of the room equals 66 sq. ft. times 8.27 ft. or 545 cu. ft.

- c. The minimum room volume on the basis of the equation in s. SPS 323.06(3) is:

$$\text{Volume} = \frac{100,000 \text{ BTU furnace} + 33,000 \text{ BTU water heater}}{1,000} \times 50 \text{ cu ft} = \underline{6650 \text{ cu. ft.}}$$

Since the 545 cu. ft. is smaller than 6650 cu. ft., the utility room is too small and another method of supplying combustion air must be used.

2. Try Method 1 again, but draw combustion air from the whole basement via openings in the utility room walls.
  - a. The volume of the room equals 1000 sq. ft. times 8.27 ft. or 8270 cu. ft. which satisfies the calculated required volume of 6650 cu ft above.
  - b. Two openings are required (high and low), each sized as follows:  
  
 Opening Area =  $\frac{(100,000 \text{ BTU} + 33,000 \text{ BTU})}{1,000} = 133 \text{ sq. in.}$
  - c. This also satisfies the requirement for a minimum 100 sq in openings. (Two 1-sq. ft. = 144 sq.in. openings would suffice.)

**OR**

3. Try Method 3 per s. SPS 323.06(4)(c) single outdoor opening between the utility room and the exterior. Since the appliances are all gas-fired, this method may be used. (We could take a prorated credit per Method 3 of s. SPS 323.06(2)(d) for the utility room, but because of its smallness, we will not bother in this example.)
  - a. The minimum size of the single opening is determined as follows:  
  
 Opening Area =  $\frac{133,000 \text{ BTU}}{3,000} = 44 \text{ sq. in.}$
  - b. An 8" round duct, which provides 50 sq in, would satisfy this. However, you must also check that the combined flue collar areas of the appliances would be met:  
 The water heater has a 3" diameter collar which is  $3.14(1.5^2) = 7 \text{ sq in.}$  in area.  
 The furnace has a 6" diameter collar which is  $3.14(3^2) = 28 \text{ sq in.}$  in area.  
 The combined area is 7 sq in + 28 sq in = 35 sq in - OK
  - c. Consideration should be given to the blocking effect of screens and louvers in air intake openings. Assuming 1/8" screen, multiply the 50 sq in of the 8" diameter duct by 0.8 to arrive at 40 sq. in., which is too small and must have a transition to something like a 8" x 8" square termination of steel louver [thus  $48 \text{ in}^2 = 64 \text{ in}^2 \times 0.75$  louver factor per SPS 323.06(5)(c)] which still satisfies the requirement.

**Subchapter IV — Delivery Systems****323.07 Duct Sizing**

Table 323.07 sets minimum and maximum air velocities in ducts. Meeting minimum duct sizes reduces air noise, occupant discomfort and fan inefficiencies from too high air velocities. Meeting maximum duct sizes economizes on materials, provides adequate air throw at outlets, reduces air stratification and may help fan efficiency.

Although kitchen range hoods are not required, they shall be installed per their listing. Their installation requirements will dictate the maximum duct run based on duct size, length, elbows and termination cap type. These requirements must be followed so that excess grease is not deposited in the ducts, due to slow duct air velocities, which may be ignited by a cooktop flare up. Note that SPS 322.39(5) requires a damper on exhaust ducts.

See the commentary under 323.02 for an example of duct sizing calculation.

### 323.08(1) Ducts Used for Other Purposes

**Question:** Can electrical, telephone or cable TV wiring be run through air return or supply ducts? Can supply ducts be run through air return ducts or joist spaces used as returns?

**Answer:** No, with three exceptions per National Electrical Code 300-22:

- Teflon-insulated wiring.
- Metal enclosed wiring.
- Romex wiring run perpendicularly to the length of a joist or stud space used as a return air plenum.

The department will also allow water and waste piping run perpendicularly through a duct if no pipe joints or cleanouts are within the duct. All penetrations have to be sealed to maintain duct pressures and prevent air leakage. In addition the size of the penetrating utility through the duct can **NOT** affect the velocity or capacity of the duct to transmit the required air volume of the duct.

**Question:** Is there a maximum length of “flex-duct” that is allowed by the Code?

**Answer:** No, many people feel that since the Commercial Building Code limited duct length, the UDC also should. There is no maximum length in the code; however, you must not exceed the static pressure loss in Table 323.07 for air distribution systems. Therefore, from a practical standpoint, flex-ducts will need to be less than 10-14 feet. In no case shall the minimum/maximum velocities **or** the maximum static pressure losses be exceeded. Also note that there is a listing [and price] difference between flex-duct and flex-connector, which are tested to different standards and have different material limitations. For example the current commercial code does not limit flex-duct length, however flex-connector length is limited to 14’.

For exhaust fans, it may be necessary to increase the fan capacity if the static pressure loss is excessive due to a restrictive duct system. This is not to say that adequate support of flex-duct or flex-connectors should be ignored, as the listing for these products do have maximum bend radius and acceptable dip limitations. Per the adopted SMACNA HVAC Duct Construction Standards – Metal & Flexible, in section S3.35, flex duct shall be supported every 5’ with no more than 2-1/2” dip between supports.

323.09(1) Volume and Backdraft Dampers

Register dampers **do not** satisfy the requirement for volume duct dampers due to their looseness.

If duct volume dampers will be concealed behind finish materials, access panels shall be provided to allow future adjustment. Alternatively, dampers may be placed behind registers, which could be removed for future access to the dampers. This is now a requirement listed in SPS 323.09(1)(b) to have access to the dampers for adjustment at later times.

323.09(2)(b) Return Air Openings

**Question:** Is it necessary to have a return air opening in each room that has a supply air opening?

**Answer:** No. If doors are undercut or other air transfer means are provided, it would not be necessary to have a return air opening in each room. However, the air must at least be transferred to a return duct serving the same floor level.

**Question:** In a two-story house, may a return air grille, at the base of the stairs to the second floor, serve the second floor? (Can the stairway serve as a return air system?)

**Answer:** No. Per this code section there must be return grilles located on both floors.

323.10(1) Solar System Piping

**Question:** Can PVC (plastic) piping be used in a solar wet-heat system?

**Answer:** Section SPS 323.10 addresses the subject of piping for wet-heating systems. However, this section does not speak specifically to the kind of piping materials. It only says that the material shall accomplish the calculated results without stress or other detriment.

This section is also supplemented by s. SPS 371.25, Liquid Systems, of the Solar Energy Systems Code which became effective July 1, 1986. The Solar Energy Systems Code includes voluntary construction quality standards for solar collectors and their supporting mechanical systems.

Section SPS 371.25 does allow plastic piping for some systems if the material meets s. SPS 384.30 of the Plumbing Code.

## Subchapter V — Chimneys and Vents

323.11(1) Summary of Common Vent and Chimney Types.

Classification	Other names	Cont. °F	Max. °F	Use	Clearance
1. Single-wall metal pipe	Class C	--	--	Only as connector in residence	Per SPS 323.045 and 323.15
2. BW vent	--	550°	--	Wall furnace (2"x4" wall)	Per listing
3. B vent	Gas vent	470°	--	Listed gas appliance with hood	B-1" to B-3"

					B-2"x 4", B-2"x 6"
4. L vent	Oil vent	570°	--	Gas or oil appliance per listing	L-1" to L-3"
5. Residential type factory-built chimney	Class A All-fuel Solid-fuel Metal Chimney				
a. Standard		1000°	1700°	Gas, oil and solid fuel appliances except closed-chamber solid fuel appliances	1" – 2"
b. HT (high temperature)		1000°	2100°	Includes closed chamber solid-fuel appliances	1" – 2"
6. Masonry chimney with liner	--	(1000°)	1800°	Includes closed chamber solid-fuel appliances	1" – 2" 21.30(9)
7. Factory-built fireplace and chimney package	--	--	--	Per listing	Per listing

### 323.11(1) Power Venters

**Question:** Can power-vented appliances be used?

**Answer:** Yes. There are two types of power-vented appliances. One type is designed, manufactured and listed as a unit. These are installed per their listing.

The second type is an add-on power venter designed and manufactured by a manufacturer other than the appliance manufacturer. These units must be tested and listed for connection to specific appliance types.

Co-venting with either type must be done strictly per their listing because of possible backdrafting and variable pressure conditions.

### 323.11(2)(b) Horizontal Vent Termination

**Question:** What is required for vent sizing when multiple appliances share a common vent and equipment is changed or replaced?

**Answer:** Gas vents are to be sized for the appliances **currently** connected to them. Therefore, if the new equipment is either larger or smaller, the common vent may have to be altered in size. This applies replacement equipment.

### 323.13 Physical Guarding of Chimneys and Vents

**Question:** Does an accessible chimney or vent need to be guarded against physical damage when located in a space like a garage?

**Answer:** Yes, normally a metal chimney usually does require to be guarded as part of its listing. A metal vent **may** require guarding as part of its listing.

### 323.14(2) Dryer Venting


Clothes dryers and their venting systems are the source of many dwelling fires, often due to accumulations of lint, in improperly installed vents, that are ignited by malfunctioning dryers. It is important to follow the UDC and the dryer manufacturer's installation instructions.

**Question:** This section requires all dryers to be vented with rigid, smooth-walled materials. Does this prohibit flexible duct?

**Answer:** No, this section also requires the exhaust connection to the dryer to be per the dryer manufacturer's installation recommendations. Many dryer installation manuals permit a short length of flexible metal duct material (connector or transition) to be installed between the dryer and the rest of venting system, to allow for ease of connecting and disconnecting of the vent system from the dryer. Per the UDC, this flexible duct shall not be concealed.

The installation instructions include maximum vent lengths to avoid accumulations of lint due to low vent velocity. It is important to follow these instructions, including accounting for any elbows or bends, type of vent termination cap and the use of any flexible connector or transition duct. Listed booster fans may be used to extend the vent lengths.

Some electric clothes dryer installation instructions also require the use of non-metallic vent material for all portions of the vent as is required by the UDC for gas clothes dryers.



### Exit Terminals of Mechanical Draft and Direct-Vent Venting Systems.

Above diagram shows gas vent terminal clearances from the Appendix of NFPA 54 standard.

## Subchapter VI — Fuel Supply Systems

323.16(1) LP Gas Storage Tanks

Section SPS 323.16(1) states that LP gas tanks are subject to Ch. SPS 340, LP Gas Code. That SPS 340 adopts NFPA 58 – 2011, Standard for the Storage and Handling of Liquefied Petroleum Gases, which is summarized below. (Piping after the first stage regulator, with some exceptions, is subject to NFPA 54, National Fuel Gas Code which is adopted by s. SPS 320.24). We recommend you purchase the actual codes from NFPA at address shown in Table 320.24-10.


*The following NFPA 58 and SPS 323 sections summarize this section.*

<u>NFPA 58</u>	<u>SPS</u>	
	340.43	Installer of a tank or tanks of 125 gallon or larger capacity shall have certificate of installation form SBD 9656 and if over 2000 gallons shall notify the local fire department within 10 days.
[6.3.1]		See attached excerpted table and figures for minimum distances between tanks and nearest other tank, important building or adjoining property line.
[6.2.1]	323.16(1)(b)	No LP tanks inside dwellings.
[6.4.4.3]		Loose or piled combustible material and weeds not permitted within 10 feet of tank.
[6.6.3.1]	323.16(1)(c)	Tanks to have welded steel supports and to be installed on concrete pads or foundations.
[6.4.5.3]		No barriers around tank to trap leaked gas or to impede firefighting.
[6.6.1.2]		Tank protected against damage by vehicles where likely. (Four-foot tall concrete filled 6-inch steel posts are acceptable.)
[6.6.1.4]		Tanks to be properly painted.
[6.8.1.3]		First stage regulators to be outside of buildings.
[6.8.1.1]		Install first stage regulator downstream of tank shutoff valve.
[6.8.1.4]		Regulators to be securely anchored. Regulator outlet to be protected to prevent entry of ice, snow or debris.
[6.8.1.5]		Regulator pressure relief outlet to at least 3 feet horizontally away from any building opening below the level of such outlet.
[6.8.1.6]		Min. 5' between pressure regulator relief outlet and sources of ignition, including direct vent exhaust or intakes or mechanical

323.16(1)

ventilation air intakes.

Figures below are from Appendix of NFPA 58-2004 standard.




For SI units, 1 ft = 0.3048 m

Note 1: 5-ft minimum from relief valve in any direction away from any exterior source of ignition, openings into direct-vent appliances, or mechanical ventilation air intakes. Refer to 6.3.7.

Note 2: If the cylinder is filled on site from a bulk truck, the filling connection and vent valve must be at least 10 ft from any exterior source of ignition, openings into direct-vent appliances, or mechanical ventilation air intakes. Refer to 6.3.9.

Note 3: Refer to 6.3.7.



For SI units, 1 ft = 0.3048 m

Note 1: Regardless of its size, any ASME container filled on site must be located so that the filling connection and fixed maximum liquid level gauge are at least 10 ft from any external source of ignition (e.g., open flame, window A/C, compressor), intake to direct-vented gas appliance, or intake to a mechanical ventilation system. Refer to 6.3.9.

Note 2: Refer to 6.3.9.

Note 3: This distance may be reduced to no less than 10 ft for a single container of 1200 gal (4.5 m<sup>3</sup>) water capacity or less, provided such container is at least 25 ft from any other LP-Gas container of more than 125 gal (0.5 m<sup>3</sup>) water capacity. Refer to 6.3.3.

323.16(2) Oil Storage Tanks

Section SPS 323.16(2) states that oil tanks are regulated by SPS 310, Flammable and Combustible Liquids Code, which covers oil equipment and is summarized below:

SPS 310 & NFPA 31

Ch. ATCP 93 adopts NFPA 31-2006, Standard for the Installation of Oil-Burning Equipment, for tank requirements, which are summarized below for inside tanks. Consult the code and standard for further details.

- 4.3.1 Tank normally located in lowest building level
- 7.5.8 Minimum 5' between tank and any source of heat.
- 7.5.9(1) Tank pitched 1/4" per foot to outlet.
- 7.5.9(2) Shutoff required at outlet of tank.
- 7.5.11 Both fill pipe and vent pipe installed on tank.
- 7.5.11.2 Vent pipe larger than largest withdraw or fill pipe or 1¼" minimum diameter.
- 7.5.11 Fill pipe and vent pipe to terminate outside.
- 7.5.12 Gauging device required on tank.
- 7.5.14 Tanks provided with rigid non-combustible supports
- 8.2.1 Piping to be metallic.
- 8.3.2(1) Fill pipe terminates at least 2' from any building opening at same or lower level.
- 8.3.4 Metal cover required on fill pipe.
- " Oil fill pipe to be identified.
- 8.7.1 Vent piping pitched to tank.
- 8.7.3 Vent pipe protected from physical damage.
- 8.7.5 Vent pipe to terminate at least 2' from any building opening.
- 8.7.6 Weatherproof hood required on vent termination.
- 8.7.5.1 Vent to terminate above snow or ice level
- 8.7.11 Vent to terminate at least 5' from any air inlet or flue gas outlet of any appliance.
- 8.8.3 Gauge to visually or audibly tell tank filler when tank is full.
- 8.9.1 Piping to be tested.

323.16(2) Gas Piping Systems

This National Fire Protection Association Standard (NFPA) Standard 54 – 2015 is adopted by the code for gas piping installation only. The requirements of the National Fuel Gas Code are summarized below.

**Question:** Is copper piping for natural gas permitted within a dwelling?

**Answer:** Yes, if, per s. 5.6.2.3 of NFPA 54, there are no more than 0.3 grains of hydrogen sulfide per 100 cubic feet of gas. To this department's knowledge, all gas delivered to Wisconsin meets this limit. Installations conforming with NFPA-54 are acceptable and comply with the UDC. Municipalities or local utilities may not require the use of only black iron pipe if the installation complies.

NFPA 54-2006Part 1 General

- 1.1.1.1 Code applies from point of delivery to gas utilization device for both natural and LP gases.

["Piping" includes pipe (rigid) and tubing (flexible).]

Part 5 Design, Materials and Components

- 5.4.1 Piping sized to provide an adequate supply of gas - see following tables.
- 5.6.2 Acceptable pipe - steel (black or galvanized), wrought iron, copper\*, brass\*, aluminum alloy (aboveground interior only).
- 5.6.3 Acceptable tubing - copper (Type K or L), aluminum alloy (aboveground interior only), steel or CSST (corrugated stainless steel tubing).
- 5.6.4.1 Plastic pipe and tubing acceptable for underground exterior uses only. (Plastic LP gas piping per NFPA 58.)
- 5.6.8 Acceptable joints and fittings.
- 5.6.8.1 - Pipe - threaded, flanged, brazed, welded, flared (nonferrous).
- 5.6.8.2 - Tubing - AGA approved tubing fittings, brazed (1000 DF min., no phosphorous), flared.
- 5.6.7.4 Pipe dope or tape on threaded joints unless not required by fitting manufacturer.
- 5.8.5.1 No sources of ignition (electrical equipment, flue gas exhausts, combustion air intakes, etc.) within 3 feet of line pressure regulator vents.
- 5.8.5.1(1) Interior pressure regulators to be vented outside or vent-limited.
- 5.8.5.2 Per NFPA 58 6.8.1.5, pressure relief device of a LP gas line regulator to be vented so the outlet, per s. 6.7.4.5, LP is no less than 3 feet horizontally away from any building openings below the outlet; and per s. 6.8.1.6, is no less than 5' from sources of ignition, openings into direct vent appliance or mechanical ventilation intakes.

5.12 Listed shutoff valves

Part 7 Installation

- 7.1.2.1 Underground piping to have 18" cover, 12" if not subject to hazard.
- 7.1.5 Underground piping to be sleeved and caulked at foundation entrance.
- 7.1.6.1 Piping underneath buildings in a conduit vented to outside and sealed at building entrance.
- 7.2.1 Aboveground exterior piping securely supported and coated or wrapped at foundation entrance.
- 7.2.4 Piping not allowed in:  
 - Clothes chute.  
 - Chimney or gas vent.  
 - Dumbwaiter or elevator shaft.  
 - Ventilating duct, but okay in combustion air duct.
- 7.2.5.2 Piping support on center spacing:  
 - Pipe – ½" - 6', - ¾" or 1" - 8'; - 1-¼" - 10'  
 - Tubing – ½" - 4'; - 5/8" or 3/4" - 6'; - 7/8" or 1" - 8'  
 Vertical piping must be supported a minimum at each floor.  
 CSST per manufacturer
- 7.3.2 Only the following fittings are allowed in concealed piping:  
 - Threaded elbows, tees, couplings, caps and plugs  
 - Brazed fittings.  
 - Welded fittings  
 - Listed CSST and press-connect fittings
- 7.3.3 Piping not allowed in solid (such as concrete) partitions.
- 7.3.4 Tubing, if not rigidly secured, can be concealed in partitions if protected against nail penetration with 0.05" thick or 16 gauge sheet metal or equivalent at penetrations of studs, plates and firestops and 4" beyond.(Note that per CSST standard, protection requires for 5" beyond member with hardened steel plate.)

- 7.3.5.2 Piping in slab floors to be laid in channels with removable covers or must have minimum 1-1/2" concrete around them.
- 7.7.1 Outlets:
- 7.7.1.2 - Not allowed behind doors.
- 7.7.1.4 - Unthreaded portion of pipe to protrude at least 1" out of walls and ceilings and
- 7.7.1.5 - 2" above floors (quick connect devices exempt).
- 7.7.2.1 - To be capped when not used.
- 7.9.1 Gas shutoff valve required upstream of pressure regulator.
- 7.9.2.2 Exterior shutoff valve required at each building served.
- 7.13.1 Piping to be electrically continuous and bonded to any grounding electrode (may use equipment grounding conductor) but not to be used as a grounding electrode.
- 7.13.2 CSST to be bonded to the electrical service grounding conductor or lightning protection grounding electrode with a minimum #6 copper conductor of a maximum 75' length. Wisconsin has a product approval for a type of CSST that does not an additional bonding conductor.

## Part 8 Testing

Installer shall test system at the greater of 3 psi or 1-1/2 times working pressure for at least 10 minutes prior to putting in service. If pressure drop is detected, then joints shall be tested with gas detector, soap and water or equivalent nonflammable solution

## Part 9 Equipment (Connections to Piping)

- 9.1.17 Equipment supported not to strain piping or connections.
- 9.6.1 Equipment connectors allowed:
- 9.6.1(1) - Rigid pipe.
- 9.6.1(2) - Tubing.
- 9.6.1(3) - Listed connectors (in same room only and where not subject to damage).
- 9.6.1(4) - Listed hose connector (outdoors only).
- 9.6.1(6) - Listed nonmetallic gas hose connectors.
- 9.6.5 Equipment shutoffs:
- 9.6.5.1 - Within 6' of appliance.
- 9.6.4.1(A) - Upstream of connector.
- 9.6.4.1(A) - Union downstream of valve.

- 9.6.5.1(B) - Decorative appliances in fireplace, if listed for that use.
- 9.6.8 Sediment trap required at all appliances except lights, ranges, dryers, gas fireplaces and outdoor grilles.
- 9.6.9 Piping not to interfere with appliance servicing (24" away from access panels).

### Sizing Gas Piping

1. Determine appliance gas demand from name plate or the following Table C-1.
  - Natural Gas - Use cubic feet per hour which equals BTU input divided by average BTU heating value per cubic foot of gas (typically 1000 BTU per cubic foot).
  - LP Gas - Use BTU input.
2. Measure the length of piping from point of delivery to the most remote outlet in the building.
3. Using the appropriate table, select the column showing the measured length or next longer length. This is the only column that will be used for the whole system.
4. In the selected column, find the gas demand, or next higher demand, of the most remote outlet and piping section.
5. Opposite this demand figure, find the correct gas piping size in the far left column.
6. Proceed in a similar manner for each outlet and each section of gas piping using the same column. For each piping section, determine the total gas demand supplied by that section.

Table C-1

## Approximate Gas Input for Typical Appliances

Appliance	Input BTU per hour (Approximate)
Range, Free Standing, Domestic	65,000
Built-In Oven or Broiler Unit, Domestic	25,000
Built-In Top Unit, Domestic	40,000
Water Heater, Automatic Storage 30 to 40 Gallon Tank	35,000
Water Heater, Automatic Storage 50 Gallon Tank	50,000
Water Heater, Automatic Instantaneous (2 Gallons Per Minute Capacity (4 Gallons Per Minute (6 Gallons Per Minute	142,800 285,000 428,400
Water Heater, Domestic, Circulating or Side-Arm	35,000
Refrigerator	3,000
Clothes Dryer, Type 1 (Domestic)	35,000
Gas Light	2,500
Incinerator, Domestic	35,000

For specific appliances or appliances not shown above, the input should be determined from the manufacturer's rating.

Table C-17

Maximum Capacity of Semi-Rigid Tubing in Thousands  
of BTU per Hour of Undiluted Liquefied Petroleum Gases  
(at 11 Inches Water Column Inlet Pressure)

(Based on a Pressure Drop of 0.5 Inch Water Column)

Outside Diameter, Inch	Length of Tubing, Feet									
	10	20	30	40	50	60	70	80	90	100
3/8	39	26	21	19	--	--	--	--	--	--
1/2	92	62	50	41	37	35	31	29	27	26
5/8	199	131	107	90	79	72	67	62	59	55
3/4	329	216	181	145	131	121	112	104	95	90
7/8	501	346	277	233	198	187	164	155	146	138

Table C-4

Maximum Capacity of Pipe in Cubic Feet of Gas per  
Hour for Gas Pressures of 0.5 Psig or Less and a  
Pressure Drop of 0.5 Inch Water Column

(Based on a 0.60 Specific Gravity Gas)

Nominal Iron Pipe Size, Inches	Internal Diameter, Inches	Length of Pipe, Feet													
		10	20	30	40	50	60	70	80	90	100	125	150	175	200
1/4	0.364	43	29	24	20	18	16	15	14	13	12	11	10	9	8
3/8	0.493	95	65	52	45	40	36	33	31	29	27	24	22	20	19
1/2	0.622	175	120	97	82	73	66	61	57	53	50	44	40	37	35
3/4	0.824	360	250	200	170	151	138	125	118	110	103	93	84	77	72
1	1.049	680	465	375	320	285	260	240	220	205	195	175	160	145	135
1-1/4	1.380	1,400	950	770	660	580	530	490	460	430	400	360	325	300	280
1-1/2	1.610	2,100	1,460	1,180	990	900	810	750	690	650	620	550	500	460	430
2	2.067	3,950	2,750	2,200	1,900	1,680	1,520	1,400	1,300	1,220	1,150	1,020	950	850	800
2-1/2	2.469	6,300	4,350	3,520	3,000	2,650	2,400	2,250	2,050	1,950	1,850	1,650	1,500	1,370	1,280
3	3.068	11,000	7,700	6,250	5,300	4,750	4,300	3,900	3,700	3,450	3,250	2,950	2,650	2,450	2,280
4	4.026	23,000	15,800	12,800	10,900	9,700	8,800	8,100	7,500	7,200	6,700	6,000	5,500	5,000	4,600

Table C-6

Maximum Capacity of Semi-Rigid Tubing in Cubic Feet  
of Gas per Hour for Gas Pressures of 0.5 Psig or Less  
and a Pressure Drop of 0.5 Inch Water Column

(Based on a 0.60 Specific Gravity Gas)

Outside Diameter, Inch	Length of Tubing, Feet													
	10	20	30	40	50	60	70	80	90	100	125	150	175	200
3/8	27	18	15	13	11	10	9	9	8	8	7	6	6	5
1/2	56	38	31	26	23	21	19	18	17	16	14	13	12	11
5/8	113	78	62	53	47	43	39	37	34	33	29	26	24	22
3/4	197	136	109	93	83	75	69	64	60	57	50	46	42	39
7/8	280	193	155	132	117	106	98	91	85	81	71	65	60	55

Table C-16

Maximum Capacity of Pipe in Thousands of BTU per Hour  
of Undiluted Liquefied Petroleum Gases (at 11 Inches Water Column Inlet Pressure)

(Based on a Pressure Drop of 0.5 Inch Water Column)

Nominal Iron Pipe Size, Inches	Length of Pipe, Feet												
	10	20	30	40	50	60	70	80	90	100	125	150	
1/2	275	189	152	129	114	103	96	89	83	78	69	63	
3/4	567	393	315	267	237	217	196	185	173	162	146	132	
1	1071	732	590	504	448	409	378	346	322	307	275	252	
1 1/4	2205	1496	1212	1039	913	834	771	724	677	630	567	511	
1 1/2	3307	2299	1858	1559	1417	1275	1181	1086	1023	976	866	787	
2	6221	4331	3465	2992	2646	2394	2205	2047	1,921	1811	1606	1496	

323.16(4) Shutoff Valves

**Question:** Can a water-type valve be used as a manual gas shutoff valve?

**Answer:** No. Gas shutoff valves must be approved by AGA or UL for such use. Their approval will be indicated on the valve.

**Question:** Is a manual shutoff device acceptable on a gas fireplace starter?

**Answer:** Yes. (Gas log systems shall be installed per their listing.)

**Subchapter VII — Equipment Location and Operation**

323.17(2) Equipment Location

Section SPS 323.17(2) requires indoor equipment to be installed with a minimum of 24 inches clearance for service. This service clearance is only required on the face(s) of the equipment with service panels. Otherwise, lesser clearances as allowed by the listing are acceptable.

323.18 Equipment Operation

**Question:** Balancing and testing of every HVAC system is required by SPS 323.18(2), - can the UDC inspector ask for a copy of that balancing report or pressure test?

**Answer:** Yes, at the final inspection a copy of that documentation should be found on site. Note that the duct sealing requirements of SPS 322.43 may be related to the testing of the ventilating system, as are toilet exhausts and make-up air supplied.

Some inspectors or owners may wish to know what sort of items should this testing and/or balancing report have included. Guidance from commercial building code IBC 364.0313 on this issue could help to be used as reference in order determine what information is required to be addressed and the means by which the information may be recorded. Included below is the note from that code section:

*Note: National Environmental Balancing Bureau (NEBB) Procedural Standards, the Associated Air Balance Council (AABC) National Standards, the Sheet Metal and Air Conditioning Contractors National Association, Inc (SMACNA) as issued in "HVAC SYSTEMS Testing, Adjusting & Balancing" or equivalent balancing procedures are acceptable to the department.*

It is known SMACNA even provides general forms for use in balancing. Some of the forms in SMACNA are impractical for use in residences since the systems are so simple, but at least SMACNA does provide information on what information is required to be addressed, and the means by which the information may be recorded for future review by the contractor who balanced the system, the owner, as well as the UDC inspector &/or Dept. representative should there be any questions as to the performance of the HVAC system at a future time.

**Summary of Rules for Water Heaters Used for Space Heating**  
 Industry Services Division  
 8/22/2014

The Uniform Dwelling Code (UDC), SPS 320-325, only applies to one- and two-family dwellings built since 1980. The Wisconsin Commercial Building Code, SPS 361-366 and the Wisconsin— amended 2009 International Mechanical Code, International Energy Conservation Code, and International Fuel Gas Code apply only to commercial and multi-family dwellings. The Wisconsin Plumbing Code, SPS 381-387, apply to all buildings. Note the code from which a requirement arises, and to what buildings the requirement applies.

- **Wisconsin Boiler Code:** SPS 341.45(1) of this code exempts water heaters from the boiler code.
- **Listing:** Per SPS 323.04 and IFGC 301.3/SPS 365.0301, heating equipment shall be listed and installed per its listing. Water heaters used for space heating need to be listed for such use and their data plate shall indicate that the unit can be used for simultaneous space heating. IFGC 624 specifies that they be listed per ANSI Z21.10.1 or ANSI Z21.10.3. These standards are intended for dual use, which means that in addition to the heating use, the water heater shall also be used for potable use, which may be satisfied with at least one properly-connected plumbing appliance or fixture. (A hose bibb is considered a fixture.)
- **Unlisted Space-Heating Only Equipment:** Space-heating only usage would be considered an unlisted use of water heaters, listed per ANSI Z21.10.1 or ANSI Z21.10.3 for dual-use. SPS 365.0301(2) for gas-fired appliances, and SPS 364.0301(3) for other fuels, allow unlisted equipment if a Wisconsin-registered engineer or architect tests the appliance output and safety controls to these or other appropriate standards as determined by the manufacturer. This may be done for each installation or the manufacturer may obtain a Wisconsin Material Approval for repetitive installations. These material approvals may also be valid under the UDC.
- **Efficiency:** Federal appliance efficiency standards have precedence over Wisconsin's efficiency requirements for smaller appliances, if there is a standard developed for a specific unit. Federal rules require that a manufacturer meet the standard for the type of appliance that the manufacturer is marketing the unit as. There is a federal standard for potable water heaters. There is a federal standard for boilers, which would apply to water heaters used for space heating only. There is no state or local responsibility or authority to enforce the federal rules.
- **Sizing:** Per SPS 323.04(5), SPS 364.1001, IFGC 624 for gas appliances, and SPS 382.40(5) (a), a dualuse water heater shall be sized to provide sufficient hot water to supply both the daily and hourly peak loads of the building.
- **Plumbing Code:** Any equipment or piping that comes in contact with potable water must meet the potable water plumbing materials standards. (A Wisconsin Plumbing Products Approval is not required.) The installation of the system that comes in contact with the potable water system must be installed by a properly-credentialed plumber. A floor drain must be provided for the water heater, if the water heater is installed on the lowest floor level. If a heat exchanger is used and only non-toxic grade additives are used, it may be a single-wall heat exchanger. If toxic additives are used, then the heat exchanger shall be a vented, double-wall heat exchanger as required by SPS 382.41(3) (d). The valving and safety devices on the system must comply with the Wisconsin Plumbing Code.
- **Non-potable piping:** If the listing, engineer/architect statement, or Wisconsin Material Approval permits the installation of backflow prevention at the water heater inlet or isolation of the water heater, then non-potable piping and devices may be used. Non-potable, heat distribution piping shall comply with Chapter 12 of the IMC.
- **Backflow Protection:** If backflow protection is installed before the water heater, then the building's water system is no longer available for expansion of the heated water. A temperature-pressure relief valve must be selected in coordination with the backflow preventer. There needs to be an expansion tank or other expansion means provided. These items, if allowed, shall be installed per the water heater's listing.
- **Temperature Setting:** Per s. 704.06 of the Wisconsin statutes, a residential landlord shall set the potable water heater temperature no higher than 125 degrees F. Per SPS 381.01(126) of the Plumbing Code, the minimum water temperature for hot potable water is 110 degrees F.
- **Isolated Water Heaters:** If a water heater is installed with no connection to the potable water system, then typically, proper water expansion means shall be provided per the water heater's listing.

## 323.18

• **Pipe Insulation:** Per SPS 322.44 , heating pipes shall be insulated to a minimum of R-3. Per IECC 403.3 requires mechanical system piping capable of carrying fluids above 105o F or below 55o F to be insulated to a minimum of R-3. IECC 403.4 requires all circulating service hot water piping in low rise residential buildings with three tenants or more is to be insulated to a minimum of R-2. IECC 503.2.8 defines minimum insulation requirements for all piping serving as part of a heating or cooling system in commercial buildings, or high rise residential buildings four stories or more above grade with three tenants or more. IECC 504.5 defines minimum insulation requirements for automatic circulating hot water systems installed in commercial buildings or high rise residential buildings four stories or more above grade.

• **Combustion Air:** Combustion air shall be provided per SPS 323.06, IFGC 304 for gas-fired appliances or IMC 701 for all other fuels.

For more information, contact your local building inspector or the Department Safety and Professional Services, 608 -266-2112.

## Optional Uniform Dwelling Code (UDC) Makeup and Combustion Air Worksheet (1/12/09)

**Project Address** \_\_\_\_\_ **Completed by:** \_\_\_\_\_ **Tel.** \_\_\_\_\_

**Background:** The UDC applies to all one and two family dwellings built since June 1, 1980. Section SPS 323.02 of the UDC requires that outside **makeup air** be supplied to balance mechanical exhaust ventilation, including required bathroom fans, so that adequate air change occurs, without backdrafting of open combustion heating appliances. Section SPS 323.06 of the UDC requires that adequate **combustion air** be supplied to heating appliances for complete fuel combustion and flue gas venting purposes, which should minimize carbon monoxide hazards. This worksheet demonstrates compliance with both requirements.

If your dwelling does not have any open-combustion **space- or water-heating** appliances, ~~then you do not have any combustion air requirements and, by code,~~ then you can rely upon infiltration through building cracks for **makeup air**. Open combustion appliances are those which use air from within the dwelling for combustion. If you don't have **any** open combustion appliances, including gas clothes dryers or ranges, then you don't need combustion air.

**NOTES: Typical appliance values** are given in the tables, however use actual values if known.

**Round pipe** has the following areas: 3" dia. pipe - 7 sq in, 4" - 12 sq in, 5" - 20 sq in, 6" - 28 sq in, 8" - 50 sq in, 10" - 79 sq in, 12" - 113 sq in.

**Opening Restrictions:** If louvers or screening is provided on an opening, then multiply its gross area by the following factors to obtain the net area (alternatively, knowing the net area, divide to obtain the gross area): 1.0 for 1/4" hardware cloth, 0.8 for 1/8" screen, 0.75 for metal louvers, 0.5 for metal louvers and 1/8" screen, and 0.25 for wood louvers [per SPS 323.06(5)(c)].

**A. Makeup Air** - Complete the following table for exhaust fans, but not recirculating, whole house fans, attic fans or inlets of balanced ventilation systems.

<b>Intermittent Exhaust Fans</b>	<b>Typical Exhaust CFM</b>	<b>OR Actual CFM</b>	<b>Number</b>	<b>Total (cfm)</b>
Bathroom fan (min. 50 cfm)	75		x	
Resid. kitchen range hood	180		x	
Downdraft range exhaust	400		x	
Electric clothes dryer	175		x	
Gas clothes dryer	150		x	
<b>SubTotal</b>				
<b>Intermittency Adjustment Factor</b>				X .40
<b>Adjusted Total</b>				
<b>Any constant exhaust fans without dedicated makeup air</b>				+
<b>Net Grand Total Makeup Air Required</b>				

You can provide makeup air via the following methods (check appropriate boxes). Note that openings or ducts shall be provided between the source of the makeup air and the exhaust fans.

- Intake fans with a capacity equal to the Grand Total above.** If ducts are connected to the fan, the fan capacity shall be appropriately adjusted.
- Openings to the outside, ducted to the return plenum of the furnace** to provide tempering and distribution. Multiply the Grand Total by the appropriate restriction factor for louvers or screening to obtain the gross makeup air required:

\_\_\_\_\_ (Net Grand Total Makeup Air Required) ÷ \_\_\_\_\_ (Opg Restr. Factor) = \_\_\_\_\_ (Adjusted Makeup Air Req'd)

The calculated capacity for round intake duct is: 3" - 38 cfm; 4" - 69 cfm; 6" - 157 cfm; 8" - 279 cfm (Circle planned size)

Section SPS 323.02(3)(a)2. requires outside makeup air openings to have shutoff means of automatic or gravity dampening for periods when no makeup air is required. Because of this dampening requirement, you may **not** use makeup air openings for combustion air openings, which are prohibited to have dampers.

**B. Combustion Air** (Note that appliance manufacturer requirements may be more restrictive.)

There are several methods of providing combustion air, of which you will choose one for each group of appliances in a common space. First, complete the table **for open combustion appliances** on the next page to determine if you can comply with method 1 or 2, below, which allows at least some inside combustion air. Otherwise, choose another method from the next page.

**1. Inside Air (Discontinuous Vapor Retarder):** Allows combustion air to be drawn from an inside space if the building has a discontinuous vapor barrier, as is permitted at box sills by s. 322.38(2)(c)2. The space shall provide a room volume of at least 50 cubic feet per 1000 btu/hr combined input rating of all open combustion appliances in that space. **Room Interconnection:** An inside space may include several rooms if connected with **high and low openings**, with each opening providing one square inch of clear opening per 1,000 btu/hr input rating, but not less than 100 square inches each. Remember to apply the above Opening Restriction Factors for louvers on the openings.

**Room Interconnection:**

Net Sq. In Req'd at Input/1,000: \_\_\_\_\_ (Min. 100 in<sup>2</sup>) ÷ \_\_\_\_\_ (Opg. Restr. Factor) = \_\_\_\_\_ sq. in. **each opg;**

Appliance	Appl. Group Number	Typical BTU/hr Input	Actual BTU/hr Input	Total BTU/hr in Each Numbered Group of Appliances That Share a Space	Room or Interconnected (per Method 1) Space Volume	Room Volume Divided by [Total BTU/hr in Room ÷ 1,000]*
Furnace <input type="checkbox"/> Gas <input type="checkbox"/> Other		100,000		Appl. Group 1		
Gas or Oil Water heater		50,000		Appl. Group 2		
Gas clothes dryer		35,000		Appl. Group 3		
Gas fireplace		50,000				
Gas range		65,000				
Wood stove or fireplace (Input per cu. ft. of firebox capacity)		100,000				

**\*If any room, or interconnected group of rooms, provide less than 50 cu ft per 1,000 BTU/hr of all appliances within, per the last column of the table, or the dwelling has a continuous vapor barrier, then choose one of the appropriate methods below. Enter the appliance group number in front of the applicable method. You can skip to Method 4 or 5 if the room is small and isolated.**

**2. Inside & Outdoor Air (Continuous Vapor Retarder):** If dwelling has a continuous vapor barrier, and

Appl therefore cannot use method 1 of taking all air from inside, but per the above table has a room volume of at least 50 cubic feet per 1000 BTU/hr combined appliance input rating, then provide supplemental outside air via a single, direct or ducted, exterior, high opening, sized at one square inch per 5,000 btu/hr combined input rating.

**Exterior Opening:**

Net Sq. In. Required at Input/5,000: \_\_\_\_\_ ÷ \_\_\_\_\_ (Opg. Restr. Factor) = \_\_\_\_\_ sq. in.; Planned Opg. Dim.: \_\_\_\_\_

**Room Interconnection:**

Net sq. in. Req'd at Input/1,000: \_\_\_\_\_ (Min. 100 in<sup>2</sup>) ÷ \_\_\_\_\_ (Opg. Restr. Factor) = \_\_\_\_\_ sq. in. **each opg;**

**3. Single Outdoor Opening (Gas Appliances Only):** If serving only gas appliances, then provide outdoor air via a single, direct or ducted, exterior, high opening sized at one square inch per 3,000 BTU/hr combined input rating, but not smaller than the combined cross sectional areas of the appliance flue outlets in that space.

Appl  
Group#

a. Sizes & areas of flues: \_\_\_\_\_ Total flue area: \_\_\_\_\_ sq in.

\_\_\_\_\_ b. Net Sq. In. Required at Input/3,000: \_\_\_\_\_ sq in..

Greater of a. or b.: \_\_\_\_\_ ÷ \_\_\_\_\_ (Opg. Restr. Factor)= \_\_\_\_\_ sq. in.; Planned Opg. Dim.: \_\_\_\_\_

**4. Prorated Inside Air Credit Plus Outdoor Air:** Calculate the pro-rated credit for an inside space that partially meets method 1, and then make up the difference by pro-rating the outside combustion air otherwise required by method 5. **Example:** If the inside space provides only 25 cubic feet per 1,000 BTU/hr (**per last column of table above**), or half of the size required by method 1, then the additional direct or ducted outside combustion air, as calculated by method 5 can be reduced by one half.

Appl  
Group#

Pro-rating credit: **100%** - [ \_\_\_\_\_ (Actual room vol. per 1000 BTU/hr) x 2] = \_\_\_\_\_

**5. Two Outdoor Openings:** Provide outdoor air via high and low, direct or vertically ducted, exterior openings, each sized at one square inch per 4,000 BTU/hr combined input rating; or via horizontally ducted openings, each sized at one square inch per 2,000 BTU/hr combined input rating.

Appl  
Group#

Direct or Vertical Ducts: Sq In Required at Input/4,000: \_\_\_\_\_ sq in x \_\_\_\_\_ (Credit from 4.) = \_\_\_\_\_ sq in.

Horizontal Ducts: Sq In Required at Input/2,000: \_\_\_\_\_ sq in x \_\_\_\_\_ (Credit from 4.) = \_\_\_\_\_ sq in.

Net Sq. Inches Required: \_\_\_\_\_ ÷ \_\_\_\_\_ (Opg. Restr. Factor) = \_\_\_\_\_ sq. in.; Planned Opg. Dim.: \_\_\_\_\_