

## Attention

Effective Date: September 12, 2012

Electrical Inspectors, Contractors, Designers and Material Suppliers

Topic: UL Listed Fire Resistive Cable

As of September 12, 2012, Underwriters Laboratories no longer will authorize manufacturers to place the UL mark on the following products:

- UL Classified Fire Resistive Cable
- UL Listed cable with "-CI" suffix (Circuit Integrity)

**This decision may affect emergency feeders designed and installed under NEC-2008 700.12(D)(2) and feeders supplying fire pumps designed and installed per NEC-2008 695(6)B(3).**

In accordance with UL, the Department of Safety and Professional Services provides the following guidance on this topic:

- UL Classified Fire Resistive Cable installed prior to 9/12/2012:  
The Department will not require changes to any installation that complied with electrical Code and the listing restrictions at the time of original installation.
- Projects using UL Classified Fire Resistive Cable permitted, approved or under construction as of 9/12/2012:  
The Department will accept any product listed and marked as an electrical circuit protective system under UL 2196. The Department will not accept any product previously listed as a circuit protective system for which the UL or FM mark can no longer be applied.
- Projects using UL Classified Fire Resistive Cable that have not been approved, permitted or in construction by 9/12/2012(Future Projects):  
The Department will accept any product listed and marked as an electrical circuit protective system under UL 2196.  
<http://www.ul.com/global/eng/pages/offering/perspectives/regulator/fire/cables/>