UPGRADE BY UST USE

Vehicle fueling

Commercial Fueling

YES

(Fed. Reg. System)

Leak detection,
Corrosion protection, &
Spill & overfill protection

December 22, 1998

NO

Tank larger than 1,100 gal.

YES

Leak detection,
Corrosion protection, &
Spill & overfill protection

December 22, 1998

NO

[10.771(1)]
[10.52(1)]

Corrosion protection, on
tank & piping,
Spill & overfill protection

May 1, 2001

Heating fuel



Tank larger than 4,000 gal.

YES

[10.773(1)]
[10.772]

Leak Detection

May 1, 1995

AND

[10.771(1)]
[10.52(1)]

NO

[10.771(2)]
[10.772]
[10.773(2)]

Tightness Test

(EXCEPTION HOME HEATING FUEL)

May 1, 2001

every 2 yr. thereafter

OR

[10.773(2)a3]

Corrosion protection on
tank and piping,
Spill & overfill protection

May 1, 2006