

Program Letter

Bureau of Storage Tank Regulation
Reissue 01/98

Classification of USTs on Residential Property

Residential property has several classifications which influence how an underground storage tank (UST) will be classified for regulatory compliance under the ILHR 10 code. The following schematic reflecting program policy, was initially developed in 1993 to assist in determining the regulatory status of USTs located on residential property.

I. Tank located on residential property of a 1 or 2 family

Tank > 1,100 gallon



Vehicles being fueled are used by residents of the property




Residential Non Federally Regulated

II. Tank located on an Comm Chapter 57 (apartment, health hotel/motel, campground, etc.) residential

Tank > 1,100 gallon



Are the vehicles fueled used: a) by the residents
b) for property



Residential Non Federally Regulated