

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,  
into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 15, Insert 15B, Page 1 of 1  
Insert between pages 298 and 299

---

**Comm 62.1507 Roof slope. (1)** This is a department exception to the requirements in IBC section 1507.12.1: Thermoset single-ply membrane roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

**(2)** This is a department exception to the requirements in IBC section 1507.13.1: Thermoplastic single-ply membrane roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

**(3)** This is a department exception to the requirements in IBC section 1507.14.1: Sprayed polyurethane foam roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

**(4)** This is a department exception to the requirements in IBC section 1507.15.1: Liquid-applied roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.