

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 30, Insert 30A, Page 1 of 1
Insert between pages 554 and 555

Comm 62.3006 Machine rooms. (1) ACCESS. This is a department informational note to be used under IBC section 3006.1:

Note: See ch. Comm 18 for additional machine room access requirements. Those requirements include a prohibition against accessing an elevator machine room through a toilet room, sleeping room or private space; and a prohibition against accessing other spaces in a building through an elevator machine room.

(2) PRESSURIZATION. This is a department exception to the requirements in IBC section 3006.3: An elevator machine room which serves a pressurized elevator hoistway and which is not directly connected to the pressurized elevator shaft is not required to be pressurized.

(3) SHUNT TRIP. Substitute the following wording for the requirements in IBC section 3006.5: Where elevator hoistways or elevator machine rooms containing elevator control equipment are protected with automatic sprinklers, a means installed in accordance with NFPA 72, section 6.15.4, Elevator Shutdown, shall be provided to disconnect automatically the main line power supply to the affected elevator prior to the application of water. This means shall not be self-resetting. The activation of sprinklers outside the hoistway or machine room shall not disconnect the main line power supply.

(4) PLUMBING SYSTEMS. Substitute the following wording for the requirements in IBC section 3006.6: Plumbing systems not used in connection with the operation of the elevator may not be located in elevator equipment rooms.