

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 30, Insert late addition 1 (Dec. 14, 2011), Page 1 of 3
Insert between pages 552 and 553

Comm 62.3001 Elevators.

(1) REFERENCED STANDARDS. Substitute the following wording for the requirements in IBC section 3001.2: Except as otherwise provided for in this code, the design, construction, installation, alteration, repair and maintenance of conveyances and their components shall comply with ch. Comm 18.

(2) CHANGE IN USE. Substitute the following wording for the requirements in IBC section 3001.4: A change in use of an elevator from freight to passenger, passenger to freight, or from one freight class to another freight class shall comply with ch. Comm 18

Comm 62.3002 Elevator car to accommodate ambulance stretcher. Substitute the following wording for IBC section 3002.4:

(1) Where passenger elevators are provided, at least one elevator shall be provided for fire department emergency access to all floors served by passenger elevators in all of the following situations:

(a) A building four or more stories above or four or more stories below grade plane.
(b) Any floor above or below the level affording fire department vehicle access, if the floor accommodates any one of the following occupancies:

1. Group I.
2. R-2.

3. Outpatient clinic and ambulatory health care facility.

2) The elevator car provided for fire department emergency access shall be of such a size and configuration to accommodate an ambulance stretcher 24 inches by 84 inches with not less than 5-inch radius corners, in the horizontal, open position.

(3) The elevator car provided for fire department emergency access shall be identified by the international symbol for emergency medical services, star of life. The symbol may not be less than 3 inches high and shall be placed inside on both sides of the hoistway door frame.