

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 7, Insert 7D, Page 1 of 1  
Insert between pages 102 and 103

---

**Comm 62.0707 Fire barriers.** Substitute the following wording for IBC section 707.5:  
Fire barriers shall extend from the top of the foundation; or horizontal assembly constructed in accordance with IBC section 712; or floor/ceiling assembly below to the underside of the floor or roof sheathing, slab or deck above, or to the underside of the horizontal assembly constructed in accordance with IBC section 712 and shall be securely attached thereto. Such fire barriers shall be continuous through concealed spaces, such as the space above a suspended ceiling.