

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 7, Insert 7F, Page 1 of 1

Insert between pages 118 and 119

---

**Comm 62.0716 Ducts and air-transfer openings. (1) PENETRATIONS OF SHAFT ENCLOSURES.** This is a department exception to the requirements in IBC section 716.5.3: Smoke dampers are not required in ducts that are used in the exhaust portion of laboratory ventilating systems which are designed and installed in accordance with NFPA 45.