

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 7, Insert 7G, Page 1 of 1
Insert between pages 120 and 121

Comm 62.0716 Ducts and air-transfer openings. (2) SMOKE DAMPERS IN HEALTH CARE FACILITIES. This is a department exception to the requirements in IBC section 716.5.5: Smoke dampers are not required in Group I-2 duct penetrations of smoke barriers in fully ducted HVAC systems.