

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 9, Insert 9B, Page 1 of 1

Insert between pages 182 and 183

Comm 62.0902 Definitions. Substitute the following definitions and informational note for the corresponding definitions listed in IBC section 902.1:

(1) “Automatic sprinkler system” or “Automatic fire sprinkler system” has the meaning given in s. 145.01 (2), Stats.

Note: Section 145.01 (2), Stats., reads as follows: “ ‘Automatic fire sprinkler system,’ for fire protection purposes, means an integrated system of underground and overhead piping designed in accordance with fire protection engineering standards. The system includes a suitable water supply, such as a gravity tank, fire pump, reservoir or pressure tank or connection beginning at the supply side of an approved gate valve located at or near the property line where the pipe or piping system provides water used exclusively for fire protection and related appurtenances and to standpipes connected to automatic sprinkler systems. The portion of the sprinkler system above ground is a network of specially sized or hydraulically designed piping installed in a building, structure or area, generally overhead, and to which sprinklers are connected in a systematic pattern. The system includes a controlling valve and a device for actuating an alarm when the system is in operation. The system is usually activated by heat from a fire and discharges water over the fire area.”

(2) “Fire area” means the aggregate floor area enclosed and bounded by fire walls, fire barriers, exterior walls or fire-resistance-rated horizontal assemblies of a building.