

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 9, Insert 9I, Page 1 of 1

Insert between pages 202 and 203

Comm 62.0907 Fire alarm and detection systems. (4) EMPLOYEE WORK AREAS. Substitute the following wording for the requirements in IBC section 907.5.2.3.2: Where employee work areas have audible alarm coverage, the alarm system shall be designed so that visible notification appliances can be integrated into the system.