

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Building Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IBC Chapter 9, Insert 9L, Page 1 of 1  
Insert between pages 210 and 211

---

**Comm 62.0910 Smoke and heat vents, and draft curtains. (1) EXCEPTION.**

Substitute the following wording for exception 1. in IBC section 910.1: Buildings protected by an approved automatic sprinkler system.

**(2) GROUPS F-1 AND S-1.** Substitute the following wording for the requirements, but not the exception, in IBC section 910.2.1: Buildings and portions thereof used as Group F-1 or S-1 occupancies having more than 50,000 square feet in area that is undivided by full-height walls having smoke resisting characteristics which are similar to those under IBC section 910.3.5.1.