

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,  
into the International Existing Building Code, 2009 edition

Safety and Buildings Division - the Wisconsin Department of Safety and Professional  
Services

IEBC Chapter 9, Insert 9D, Page 1 of 1  
Insert between pages 46 and 47

---

**Comm 66.0901 Change of occupancy. (4) STANDPIPE SYSTEMS.** This is a department rule in addition to the requirements in IEBC section 912.2: Standpipe systems shall be provided in existing buildings and structures or portions of existing buildings and structures in accordance with chapter 9 of the IBC when existing buildings or structures that are greater than 60 feet in height are changed to include a Group R-1 or R-2 occupancy.