

Insert pages for September 1, 2011 Wisconsin Commercial Building Code, Comm 61-66, into the International Energy Conservation Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5B, Page 1 of 1  
Insert between pages 42 and 43

---

**Comm 63.0503 Building mechanical systems. (1) CALCULATION OF HEATING AND COOLING LOADS.** The following wording is a department requirement in addition to the requirements in IECC section 503.2.1: Design heating and cooling loads shall be determined in accordance with s. Comm 63.0302 and Table 63.0302.

**(2) EQUIPMENT AND SYSTEM SIZING.** Substitute the following wording for the requirements and the exceptions in IECC section 503.2.2: Heating and cooling equipment and systems shall be sized to provide the minimum space and system loads calculated in accordance with s. Comm 63.0302.