

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66, into the International Energy Conservation Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5D, Page 1 of 1  
Insert between pages 52 and 53

---

**Comm 63.0503 Building mechanical systems. (4) ECONOMIZERS SIMPLE HVAC SYSTEMS.** Substitute the following wording for the requirements in IECC section 503.3.1 the first paragraph and Table 503.3.1 (1): Supply air economizers shall be provided on the following cooling systems: (a) Package roof top units > 33,000Btu/h.  
(b) All other cooling systems > 54,000 Btu/h.

**(5) ECONOMIZERS COMPLEX HVAC SYSTEMS.** Substitute the following wording for the requirements, but not the exceptions, in IECC section 503.4.1: Supply air economizers shall be provided on cooling systems as described under sub. (4). Economizers shall be capable of operating at 100 percent outside air, even if additional mechanical cooling is required to meet the cooling load of the building.