

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Energy Conservation Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5J, Page 1 of 1
Insert between pages 58 and 59

Comm 63.0505 Lighting systems. (2) LINE-VOLTAGE LIGHTING TRACK AND PLUG-IN BUSYWAY. Substitute the following for the requirements in IECC section 505.5.1.4: The wattage of line-voltage lighting track and plug-in busway which allows the addition or relocation of luminaires without altering the wiring of the system shall be the volt-ampere rating of the branch circuit feeding the luminaires or an integral current limiter controlling the luminaires, or the higher of the maximum relamping rated wattage of all of the luminaires included in the system, listed on a permanent factory installed label, or 30 W/linear foot.