

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66, into the International Fuel Gas Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IFGC Chapter 3, Insert 3A, Page 1 of 1  
Insert between pages 16 and 17

---

**Comm 65.0300 Statutory requirements.** These are department informational notes to be used under IFGC chapter 3:

**Note:** Section 101.16 (4), Stats., requires “(a) The person actually performing the work of installing equipment utilizing liquefied petroleum gas for fuel purposes shall furnish the user of the equipment a statement, the form of which shall be prescribed by the department, showing that the design, construction, location, and installation of the equipment conforms with the rules promulgated by the department under this section.

(b) 1. A person who owns, leases, or uses a propane gas system and who is a customer of a retail supplier shall notify the retail supplier of propane gas for the propane gas system of any interruption in the operation of the propane gas system due to the replacement, modification, repair, or servicing of the propane gas system by any person other than the retail supplier. The customer shall provide the notice at least 7 days in advance of the the interruption in the operation of the propane gas system, except as provided in subd. 2. The retail supplier, or the person replacing, modifying, repairing, or servicing the propane gas system, shall perform a check for leaks or other defects in the propane gas system before placing the propane gas system back into operation in the manner required by rule.

2. If the interruption of a propane gas system subject to subd. 1. is due to emergency repair or servicing, the customer shall provide the notice to the retail supplier as soon as possible and no later than 24 hours after the repair or servicing is completed.”

**Comm 65.0301 General regulations. (1) SCOPE.** Substitute the following wording for the requirements in IFGC section 301.1: This chapter shall govern the approval and installation of all equipment and appliances that comprise parts of the installations regulated by this code.

**(2) LISTED AND LABELED.** Substitute the following wording for the requirements in IFGC section 301.3: The requirements as specified in s. Comm 64.0301 (3) shall apply.