

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,  
into the International Fuel Gas Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IFGC Chapter 3, Insert 3B, Page 1 of 1  
Insert between pages 18 and 19

---

**Comm 65.0303 Appliance location. (1) GENERAL.** This is a department rule in addition to the requirements in IFGC section 303.1: If the air entering the heat exchanger of all gas-fired equipment is 30oF or lower, the heat exchanger and burners shall be constructed of corrosion-resistant materials.

**(2) PROHIBITED LOCATIONS.** The exceptions 3. and 4. in IFGC section 303.3 are not included as a part of this code.