

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,  
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 3, Insert 3F, Page 1 of 2  
Insert between pages 26 and 27

---

**Comm 64.0309 Temperature control.** These are department exceptions to the requirements in IMC section 309.1:

**(1) ALTERNATE MINIMUMS.** For those interior spaces intended for human occupancy listed in Table 64.0309, the heating system shall be capable of maintaining an inside temperature of not less than that shown in the table at 3 feet above the floor.

**Table 64.0309**  
**Alternate Minimum Inside Temperature**

<b>Occupancy Types</b>	<b>Minimum Inside Temperature (degrees F)</b>
Dry cleaners, laundries, laundry rooms	60
Educational training shops	60
Commercial kitchens	60
Health care facilities, hospitals, nursing homes, ambulatory surgery centers	Footnote a
Factories and machine shops	60
Foundries	NMR
Sawmills	NMR
Garages at private dwellings	NMR
Automotive service and repair garages	60
Car washes, enclosed:	
Self-serve	NMR
All other types	60
Ice skating rinks (indoor)	NMR
Natatoriums	76
Roller skating rinks (indoor)	60
Storage	NMR
Elevator cars	NMR
Janitor closets	NMR

Locker and dressing rooms	70
Shower rooms	70
Food processing	NMR
Printing	60

NMR = No minimum requirement

a For inside temperature requirements in health care facilities, use American Institute of Architects (AIA) Guidelines for Design and Construction of Hospital and Health Care Facilities.

**(2) SEASONAL OCCUPANCIES.** The heating requirements but not the ventilation requirements may be waived during the period of May 1 through October 15 for the following or similar occupancies: drive-in eating places, club houses, outdoor toilets, camp lodge buildings, canning factories and migrant labor camps.