

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 4, Insert 4G, Page 1 of 1
Insert between pages 34 and 35

Comm 64.0407 Chemical and septic toilets. This is a department rule in addition to the requirements in IMC section 400: Chemical or septic toilets and composting privies are prohibited in spaces under negative pressure. Toilet rooms with chemical or septic toilets shall be provided with natural ventilation via a window, louver or skylight with at least 2 square feet of area openable directly to the outside. The opening shall be provided with a screen to limit the passage of insects and vermin.