

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,  
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 5, Insert 5A, Page 1 of 1  
Insert between pages 36 and 37

---

**Comm 64.0502 Required systems. (1)** Substitute the following wording for the requirements in IMC section 502.1: An exhaust system shall be provided, maintained and operated as specifically required by this section and for all occupied areas where machines, vats, tanks, furnaces, forges, salamanders and other appliances, equipment and processes in such areas produce or throw off dust particles sufficiently light to float in the air or which emit heat, odors, fumes, spray, gas or smoke, in such quantities to be injurious to health or safety.