

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 5, Insert 5B, Page 1 of 1
Insert between pages 42 and 43

Comm 64.0502 Required systems. (2) This is a department exception in addition to the exceptions in section IMC 502.14: The source capture system is not required when the motor vehicle exhaust system is connected directly to a noncombustible hose that is not more than 10 feet long and discharges directly to the exterior of the building.