

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 5, Insert 5C, Page 1 of 1
Insert between pages 46 and 47

Comm 64.0506 Commercial kitchen grease ducts and exhaust equipment. (2)
JOINTS, SEAMS AND PENETRATIONS OF GREASE DUCTS. (a) This is a department
alternative to the requirements, but not the exceptions, in IMC section 506.3.2: Joints, seams
and penetrations of grease ducts may be made with any other means that provide a
liquid-tight seal at 1500 oF and that are listed and labeled for the application.
(b) This is a department rule in addition to the requirements in IMC section 506.3.2.: Duct
joints may also be flanged joints.
(c) The requirements of IMC section 506.3.2.5 are not included as part of this chapter.