

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 6, Insert 6A, Page 1 of 1
Insert between pages 60 and 61

Comm 64.0601 General. Substitute the following wording for the requirements in IMC section 601.2 Exception 1: Use of a corridor as a source of makeup air for exhaust systems in rooms that open directly onto such corridors shall be permitted provided that each such corridor is directly supplied with air at a rate greater than the rate of makeup air taken from the corridor.