

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,  
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 6, Insert 6B, Page 1 of 1  
Insert between pages 62 and 63

---

**Comm 64.0602 Plenums.** Substitute the following wording for the requirements, but not the exceptions, in IMC section 602.2.1: Except as required by Sections 602.2.1.1 through 602.2.1.5, materials within plenums shall be noncombustible or shall have a flame spread index of not more than 25 and a smoke-developed index of not more than 50 when tested in accordance with ASTM E 84, CAN/ULC S102.2 or UL 723.