

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 6, Insert 6E, Page 1 of 1
Insert between pages 68 and 69

Comm 64.0607 Ducts and air-transfer openings. (1) PENETRATIONS OF SHAFT ENCLOSURES. This is a department exception to the requirements in IMC section 607.5.5: Smoke dampers are not required in ducts that are used in the exhaust portion of laboratory ventilating systems which are designed and installed in accordance with NFPA 45.

(2) SMOKE DAMPERS IN HEALTH CARE FACILITIES. This is a department exception to the requirements in IMC section 607.5.4: Smoke dampers are not required in Group I-2 duct penetrations of smoke barriers in fully ducted HVAC systems.