

Insert pages for September 1, 2011, Wisconsin Commercial Building Code, Comm 61-66,
into the International Mechanical Code, 2009 edition

Safety and Buildings Division - Wisconsin Department of Safety and Professional Services

IMC Chapter 9, Insert 9A, Page 1 of 1
Insert between pages 82 and 83

Comm 64.0918 Forced-air warm-air furnaces. (1) This is a department rule in addition to the requirements in IMC section 918.6: The outside air intake openings shall be located at least 12 inches vertical from the adjoining grade level.

(2) Substitute the following wording for the requirements in IMC section 918.6 item 2: Where located less than 10 feet above the surface of any abutting public way or driveway, or at grade level by a sidewalk, street, alley or driveway.