

INSERT PAGES
IFGC CHAPTER 6

To be inserted between pages 122 & 123.

Comm 65.0630 Infrared radiant heaters. These are department rules in addition to the requirements in IFGC section 630.1:

(1) Spaces served with unvented infrared radiant heaters shall be provided with at least 4 cfm of outside air per 1,000 Btu per hour input of installed heaters.

(2) Unvented infrared radiant heaters may be used only in the following occupancies:

(a) Groups F and S.

(b) Groups U and H only with written approval.

Comm 65.0631 Boilers. Substitute the following wording for the requirements in IFGC section 631: The provisions of ch. Comm 41 shall govern the installation, alteration and repair of boilers and pressure vessels.

Comm 65.0632 Equipment installed in existing unlisted boilers. The requirements in IFGC section 632 are not included as part of this chapter.