



**Safety & Buildings Division**  
 201 West Washington Avenue  
 P.O. Box 2658  
 Madison, WI 53701-2658

Evaluation # 200327-H

## Wisconsin Building Product Evaluation

**Infrared Heaters:**

**Manufacturer:** Thomas & Betts Corporation, Reznor Div.  
 150 McKinley Ave.  
 Mercer, PA 16137

Thomas & Betts Monterrey  
 Profr. Rodolfo Gonzalez #100  
 Monterrey, Mexico 67119

**Approved Product(s):** Trade Name: **Reznor VR Series**

Model Numbers: VR 50, 75, 100, 125, 150, 175 & 200

**SCOPE OF EVALUATION:** This review includes the cited: Comm code requirements in accordance with the current **International Building Code (IBC); International Mechanical Code (IMC); and International Fuel Gas Code (IFGC).**

**TESTS:** The infrared heaters were tested in accordance with ANSI Z83.20 Standard for Gas-Fired Low-Intensity Infrared Heaters, and CSA International 2.35a US Standard Gas-Fired Low-Intensity Infrared Heaters. The infrared heater equipment has been certified by CSA International.

**LIMITATIONS OF APPROVAL:** The infrared heaters shall be installed as allowed in **s. IBC 302.1; ss. IMC 301, 303, and 912; s. IFGC 629.1**, their listing and the manufacturer's recommendations.

This approval will be valid through December 31, 2008, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department. The product approval is applicable to projects approved under the current edition of the applicable codes. This approval may be void for project approvals made under future applicable editions. The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

**DISCLAIMER:** The department is in no way endorsing or advertising this product. The product approval is applicable to projects approved under the current edition of the applicable codes. This approval may be void for project approvals made under future applicable editions. This approval addresses only the specified applications for the product and does not waive any requirement not specified in this document.

Revision Date:  
 Approval Date: November 11, 2003 By: \_\_\_\_\_  
 Lee E. Finley, Jr.  
 Product/Material &  
 Building Plan Review  
 Integrated Services Bureau

200327-H.doc