

Wisconsin Commercial Building Inspector Certification
Chapter 3 and 4 Practice Questions

Worksheet 1

Chapter 3

Gathering of persons for purposes such as civic or social function are classified as _____.

An exothermic reaction which progresses through the unburned material at a rate less than the velocity of sound is _____.

Spaces within a building where quantities of hazardous materials do not exceed the maximum allowable quantities per table 307.1(1) are _____.

Child care facilities shall be classified as _____ providing care for more than five but no more than 100 children 2 $\frac{1}{2}$ years or less of age located on the level of exit discharge and each room has an exit door directly to the exterior.

Buildings or structures shall be classified as _____ containing materials that pose a detonation hazard.

_____ include among others, buildings use for the storage of noncombustible materials.

Educational occupancies for students above the 12th grade are classified as _____.

A room or space used for assembly purposes by fewer than ____ persons and accessory to another occupancy shall be included as part of that occupancy.

What is the occupancy classification for a church?

What is the occupancy classification for a car wash?

What is the occupancy classification for a power house?

What is the occupancy classification for an apartment building?

What is the occupancy classification for an open parking garage?

Chapter 4

A _____ is defined as a roofed or covered common pedestrian area within a building that serves as access for two or more tenants and not to exceed three levels that are open to each other.

Within each individual tenant space in a covered mall building, that maximum distance of travel from any point to an exit or entrance to the mall shall not exceed _____ feet.

The provisions of the high rise section shall apply to buildings having occupied floors located more than _____ feet above the lowest level of fire department vehicle access.

According to Wisconsin statutes an automatic sprinkler system must be installed throughout every building that is more than _____ feet high.

An opening connecting two or more floor levels is an _____.

Design and number of control areas can be found in section _____ and table _____.

Group "H" occupancies are addressed in section _____.

Control areas shall be separated from each other by _____.

Group H occupancies shall be provided with an _____ in accordance with section 907.2.

The area of openings in the exterior walls on an open parking structure tier must be at least _____ of the total perimeter wall area of each tier.