



Suggested Guidelines For The Setup And Operation Of Special Amusement Structures/Halloween Houses

Commerce Safety Services and Fire Prevention Program have received numerous questions and concerns from fire departments, service groups, and other external customers over the years regarding special amusement structures.

Haunted Houses

The following information is provided as a guideline for Commerce customers, both internal and external, on special amusement structures. This information is provided as a guideline only. It is not an official code interpretation or Commerce policy. The local fire department or authority having jurisdiction retains fire prevention authority over these structures. A municipal fire or building code official may allow a building or a portion of a building to be used temporarily in a manner that differs from the approved use for the building or space, or may approve a temporary building to be used by the public, subject to all of the provisions stipulated in either Comm 14.003(6) or Comm 61.03(11) for temporary use.

- (1) Vehicles shall be placed a minimum of 20 feet from the structure.
- (2) All decorations, wall coverings, etc., shall be fire retardant and meet with the approval of the local authority having jurisdiction (AHJ). Where used, decorations should be kept well away from all heat sources, light bulbs, heaters, etc.
- (3) Purchase only those costumes, wigs and props labeled as flame resistant or retardant. Costumes shall be made without billowing or long trailing features that present a higher risk of ignition.
- (4) "No Smoking" signs shall be displayed and no open flames, candles, torch lights or other sources of ignition should be present. Flashlights shall be used where appropriate.
- (5) Fire extinguishers, both type and placement, should comply with NFPA 10.
- (6) No flammable liquids shall be allowed within 50 feet of the structure.
- (7) No LPG tanks or cylinders shall be allowed in the structure or within 25 feet of the structure.
- (8) Housekeeping shall be maintained at all times with no straw, hay, cornstalks or dried flowers, etc., allowed in the structure.
- (9) Structure shall have a setback of 20 feet from property line and any other structures.
- (10) Structure shall meet load requirements (live, dead, and wind loads).
- (11) Two exits shall be required with the standard exit door requirement being met. In addition, all exit passageways should be a minimum of 36 inches wide, with a minimum of 2.5 F/C being required for illumination. The AHJ may modify this suggestion (2.5 F/C for illumination) by the use of attendants.
- (12) Electrical wiring and components shall meet the requirements of Comm 16/NEC 70. Extension cords may be used per Comm 14.
- (13) Smoke detection may be required by AHJ.
- (14) Sufficient attendants shall be present on-site to conduct emergency operations in case of fire or medical emergency. Children shall be supervised at all times.
- (15) Life safety hazards such as, but not limited to, the generation of artificial fog are to be subject to the approval of the AHJ.
- (16) Surfaces for walking shall be well drained and kept free of debris, obstructions, projections, tripping hazards, and other such hazards. Stair treads, etc., should meet the rate of rise and tread per Wisconsin Administrative Code.