

# SOLID FUEL-FIRED BURNING WATER-HEATING APPLIANCE CHECKLIST

Owner/Installer: \_\_\_\_\_

Location Address: \_\_\_\_\_

City, State Zip: \_\_\_\_\_

**Fuel Type:** Wood  Coal   
Corn  Dual Fuel

**Other Type Fuels** (Describe) \_\_\_\_\_

**Fired Method:** Manual  Automatic  **Waterside atmospherically vented:** Yes  No

Manufacturer \_\_\_\_\_

Model / Ser No. \_\_\_\_\_ BTU Output Rating \_\_\_\_\_ Year Built \_\_\_\_\_

Commercial Installations – (effective date 12-01-08)			UDC Installations – (effective date 12-01-08)		
Code Section	Item Description	X	Code Section	Item Description	X
URU 561.16(1)a	Inspected by certified Boiler inspector	<input type="checkbox"/>	SPS 23.04	Solid fuel fired water heating appliances that serve a one or 2-family dwelling, whether located inside or outside the dwelling, shall comply with Comm 41, Boilers and Pressure Vessels.	<input type="checkbox"/>
URU 541.41 (4)	Complete form SBD 6314 or City of Milwaukee Boiler installation permit	<input type="checkbox"/>	SPS 341.16(1)b	Inspected by certified UDC inspector	<input type="checkbox"/>
SPS 341.49 (2) a	Self-contained weather proofing or other weather protection.	<input type="checkbox"/>	SPS 341.49 (2) a	Self-contained weather proofing or other weather protection.	<input type="checkbox"/>
SPS 341.49 (2) b	Must be listed by a nationally recognized testing laboratory.	<input type="checkbox"/>	SPS 341.49 (2) b	Must be listed by a nationally recognized testing laboratory.	<input type="checkbox"/>
SPS 341.49 (2) c	Must be properly vented to prevent positive pressure condition.	<input type="checkbox"/>	SPS 341.49 (2) c	Must be properly vented to prevent positive pressure condition.	<input type="checkbox"/>
SPS 341.49 (3) a	Located away from other structures in accordance with the manufacture’s recommendations. If provided, a canopy shall be open on all sides, constructed of substantially nonflammable materials and shall not fully cover the unit.	<input type="checkbox"/>	SPS 341.49 (3) a	Located away from other structures in accordance with the manufacture’s recommendations. If provided, a canopy shall be open on all sides, constructed of substantially nonflammable materials and shall not fully cover the unit.	<input type="checkbox"/>
SPS 341.49 (3)b	Shall be enclosed by fencing or other barriers to prevent access and tampering by unauthorized persons.	<input type="checkbox"/>	SPS 341.49 (3) b	Shall be enclosed by fencing or other barriers to prevent access and tampering by unauthorized persons.	<input type="checkbox"/>
SPS 341.49 (3) c	Automatically fired water-heating appliance shall be designed, accepted and approved by the original manufacturer.	<input type="checkbox"/>	SPS 341.49 (3) c	Automatically fired water-heating appliance shall be designed, accepted and approved by the original manufacturer.	<input type="checkbox"/>
SPS 341.49 (3) d	Provide a means to prevent freezing of the water supply and return lines.	<input type="checkbox"/>	SPS 341.49 (3) d	Provide a means to prevent freezing of the water supply and return lines.	<input type="checkbox"/>
IMC 1202	Installed with piping materials and fittings suitable for temperatures of the distribution system.	<input type="checkbox"/>	SPS 323.10	Piping materials and fittings suitable for temperatures of the distribution system.	<input type="checkbox"/>
Additional Info if needed: _____					
Local Zoning & permitting	<b>Check with local municipality for procedures pertaining to Zoning and permitting requirements</b>				