

DSPS Control No.

# Weatherization Field Inspection Report

Stipulation No.  
S-

This report will be used by certified weatherization inspectors to inform owners of findings from inspection visits required under SPS 367, which is administered by the Department of Safety and Professional Services. (This is not an inspection for health and safety requirements covered by building codes.) It is not to be filed with the Register of Deeds. Upon completion of the requirements, call the inspector for a final inspection and a Certificate of Compliance.

Owners Names:		Rental building location, street address:		Manager or Other Contact Person:	
Street Address:		City:		Street Address:	
City, State, and Zip Code:		County:		City, State, and Zip Code:	
Telephone Number, including area code:		Is This A Multiple-Use Occupancy? <input type="checkbox"/> Yes <input type="checkbox"/> No		Total number of rental units in buildings: Telephone Number, including Area Code:	

**NOTE: Submit one report per building!**

If OK, check these boxes

If not OK, check the appropriate boxes for the improvement(s) needed.

- ↓
- Doors:**  Needs insulated doors or storm doors,  Needs self-closing devices on storm doors.
  - Windows, including door sidelights:**  Needs double-glazing or storm windows (including basement), Window Repairs:  Putty,  Missing Glass,  Frame.
  - Caulking or Glazing Compound:** Needs caulking→ Storm window glazing and storm door frames.
  - Weatherstripping:**  Needs weatherstripping on cracks larger than 0.1" at → Windows,  Exterior Storm and Insulated Doors
  - Blower door test**—Submit documentation per SPS 367.05 (3).  Not applicable.
  - Box Sill:** Existing R-value = \_\_\_\_\_  Not accessible,  Add R-19,  Add R-11
  - Forced air supply ducts in vented spaces:**  not applicable,  Not accessible,  Add R-5
  - Steam heating pipes in vented space:**  Not applicable,  Not accessible,  Add R-4
  - Hydronic heating pipes in vented space:**  Not applicable,  Not accessible,  Add R-2
  - Domestic water pipes in vented space:**  Add R-2 (hot and cold)→  Within 5 feet of water heater,  Entire length (circulating).  
 Not applicable
  - Shower flow restrictors:**  No shower facilities,  Add restrictors→ 3 GPM max.
  - Access panels and doors to attics and other vented spaces:**  Not applicable,  Add R-19 if horizontal,  Add R-5 if vertical.
  - Attic insulation:** Existing R-value = \_\_\_\_\_  Not accessible,  Insulate to R-38,  Add R-19  
 Add to maximum allowable level (floored attic).
  - Moisture control:** Attic→ Not accessible,  Vent needed = \_\_\_\_\_ Sq. Ft., (Existing vent area: High: \_\_\_\_\_ Sq. Ft., Low: \_\_\_\_\_ Sq. Ft.)  
Crawl space: → Not accessible/applicable, Existing vent area = \_\_\_\_\_ Sq. Ft.,  Vent needed: \_\_\_\_\_ Sq. Ft.,  Need crawl space vapor barrier.

Comments: (Please reference Inspected Area numbers)

Inspector's Name: (Please Print)	Inspector's Certificate Number:	Inspector's Business Phone Number w/ Area Code:
Inspector's Signature:	Date Signed:	Indicate Visit Number: First <input type="checkbox"/> Second <input type="checkbox"/> Third <input type="checkbox"/>

Personal information you provide may be used for secondary purposes [Privacy Law s. 15.04(1)(m)].