

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 206 & 207.

Comm 62.1007 Accessible means of egress. Substitute the following wording for the requirement under IBC section 1007.3 exception 3.: The clear width of 48 inches between handrails and the area of refuge is not required at exit stairways in buildings or facilities that are equipped throughout with an automatic sprinkler system installed in accordance with IBC section 903.3.1.1 or 903.3.1.2.

Comm 62.1008 Doors, gates and turnstiles. (1) CLEAR DOOR OPENINGS FOR NONACCESSIBLE STALLS. This is a department exception to the requirements in IBC section 1008.1.1: The clear door opening for a nonaccessible toilet stall, shower stall, or other similar compartment, may be less than 32 inches wide.