

To be inserted between pages 220 & 221.

Comm 62.1015 Refrigerated spaces. Substitute the following wording for the exception in IBC section 1015.5: Where using refrigerants in quantities limited to the amounts based on the volume set forth in ch. Comm 45.

Comm 62.1016 Exit access travel distance. (1) Substitute the following wording for the requirements, but not the exceptions, in IBC section 1016.1: (a) Exits shall be so located on each story that the maximum length of exit access travel, measured from the most remote point within a story to the entrance to an exit along the natural and unobstructed path of egress travel, shall not exceed the distances given in Table 1016.1 (b) Where the path of exit access includes unenclosed stairways or ramps with the exit access, the distance of travel on such means of egress components shall also be included in the travel distance measurement. The measurement along stairways shall be made on a plane parallel and tangent to the stair tread nosings in the center of the stairway.

(2) Substitute the following wording for the exception 3. in IBC section 1016.1: In other than occupancy Groups H and I, the exit access travel distance to a maximum of 50 percent of the exits is permitted to be measured from the most remote point within a building to an exit using unenclosed stairways or ramps when connecting a maximum of 2 stories. The two connected stories shall be provided with at least two means of egress. Such interconnected stories shall not be open to other stories. The measurement along stairways shall be made on a plane parallel and tangent to the stair tread nosings in the center of the stairway.

(3) This is a department exception to the requirements in IBC section 1016.1: In other than occupancy Groups H and I, exit access travel distance is permitted to be measured from the most remote point within a building to an exit using unenclosed stairways or ramps in the first and second stories in building equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. The first and second stories shall be provided with at least two means of egress. Such interconnected stories shall not be open to other stories. The measurement along stairways shall be made on a plane parallel and tangent to the stair tread nosings in the center of the stairway.