

To be inserted between pages 222 & 223.

**Comm 62.1017 Corridor continuity.** This is a department exception to the requirements in IBC section 1017.5: Other spaces or rooms constructed as required for corridors, and that are adjacent to a fire-resistance-rated corridor, shall not be construed as intervening rooms; and may be open to the corridor when all of the following are satisfied:

- (1) The spaces are not occupied for hazardous uses.
- (2) The spaces are not occupied for the incidental uses listed in IBC Table 508.2.
- (3) The spaces are arranged so as to not obstruct access to the required exits.

**Comm 62.1019 Minimum number of exits.** (1) Substitute the following wording for the requirements in IBC section 1019.1: All rooms and spaces within each story shall be provided with and have access to the minimum number of approved independent exits required by Table 1019.1 based on the occupant load of the story. For the purposes of this chapter, occupied roof shall be provided with exits as required for stories. The required number of exits from any story, basement or individual space shall be maintained until arrival at grade or the public way.

- (2) These are department exceptions to the requirements in IBC section 1019.1:
  - (a) As modified by Section 1015.1.
  - (b) As modified by Section 1019.2.
  - (c) Rooms and spaces within each story provided with and having access to a means of egress that complies with Exception 3 or 4 in Section 1016.1 shall not be required to be provided the minimum number of approved independent exits required by Table 1019.1 on each story.
  - (d) Buildings of Group I-3 occupancy that are used as guard towers, provided the towers are no higher than 2 stories above grade, accommodate no more than 10 occupants, and have a travel distance of no more than 75 feet.