

INSERT PAGES
IBC CHAPTER 14

To be inserted between pages 258 & 259.

Comm 62.1405 Wall coverings. (1) EXTERIOR WINDOWS AND DOORS. The requirements in IBC section 1405.12 are not included as part of this code.

(2) POLYSTYRENE SHEATHING. This is a department rule in addition to the requirements in IBC section 1405.13.1:

(a) Extruded polystyrene sheathing having all of the characteristics in [par. \(b\)](#) may be utilized as the required backing material for vinyl siding when used in accordance with all of the limitations in [par. \(c\)](#).

(b) 1. Extruded, rigid, and cellular.

2. Type IV, as specified in ASTM C 578.

3. Thickness of at least one inch.

(c) 1. On-center stud spacing of 16 inches or less.

2. Mean roof height of 40 feet or less.

3. Wind exposure category of B, or C, as established in IBC section 1609.4; and the building is not sited on the upper half of an isolated hill or escarpment meeting conditions 1, 2, and 3 in IBC section 1609.1.1.1.