

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 278 & 279.

Comm 62.1603 Construction documents. (1) FLOOD DESIGN DATA. Item 5 under the exception in IBC section 1603.1 is not included as part of this code.

(2) ROOF SNOW LOAD. Substitute the following wording for the requirements in IBC section 1603.1.3: The ground snow load, P_g , shall be indicated. In areas where the ground snow load, P_g , exceeds 10 pounds per square foot, the following additional information shall also be provided, regardless of whether snow loads govern the design of the roof:

- (a) Flat-roof snow load, P_f
- (b) Snow exposure factor, C_e .
- (c) Snow load importance factor, I .
- (d) Thermal factor, C_t .
- (e) Any sloped-roof snow load, P_s .
- (f) Any unbalanced, drift or sliding snow loads.

(3) FLOOD DESIGN. The requirements in IBC section 1603.1.6 are not included as part of this code.

(4) SPECIAL INSTRUCTIONS. The requirements in IBC section 1603.1.8 are not included as part of this code.

(5) LIVE LOADS POSTED. Substitute the following wording for the requirements in IBC section 1603.3: Where the live loads for which each floor or portion thereof of a commercial or industrial building is or has been designed to exceed 100 pounds per square foot, such design live loads shall be conspicuously posted by the owner in that part of each story in which they apply, using durable signs. It shall be unlawful to remove or deface such notices.

(6) OCCUPANCY PERMITS. The requirements in IBC section 1603.4 are not included as part of this code.