

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 112 & 113.

Comm 62.0716 Ducts and air-transfer openings. (2) SMOKE DAMPERS IN HEALTH CARE FACILITIES. This is a department exception to the requirements in IBC section 716.5.5: Smoke dampers are not required in Group I-2 duct penetrations of smoke barriers in fully ducted HVAC systems.