

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 182 & 183.

Comm 62.0907 Fire alarm and detection systems. (1) GENERAL. Substitute the following wording and informational note for the requirements in IBC section 907.1: IBC section 907 covers the application and installation of fire alarm systems and their components.

Note: See ch. Comm 14 for requirements for performance and maintenance of fire alarm systems and their components.

(2) CONSTRUCTION DOCUMENTS. The requirements in IBC section 907.1.1 are not included as part of this code.

(3) GROUP I. Substitute the following wording for the requirements, but not the exception, in IBC section 907.2.6: A manual fire alarm system shall be installed in Group I occupancies. An electrically supervised, automatic smoke detection system shall be provided throughout the occupancy, except as provided in IBC sections 907.2.6.1 to 907.2.6.3.