

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 186 & 187.

Comm 62.0907 Fire alarm and detection systems. (6) PROTECTIVE COVERS.

Substitute the following wording for the requirements in IBC section 907.3.5: The building official is authorized to require the installation of listed manual fire alarm box protective covers to prevent malicious false alarms or provide the manual fire alarm box with protection from physical damage. The protective cover shall be transparent or red in color with a transparent face to permit visibility of the manual fire alarm box. Each cover shall include proper operating instructions.