

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 194 & 195.

Comm 62.0909 Smoke control systems. (2) INSPECTIONS FOR SMOKE CONTROL. Substitute the following wording for the requirements in IBC section 909.18.8: Smoke control systems shall be tested by a qualified agency.

(3) SCOPE OF TESTING. Substitute the following wording for the requirements in IBC section 909.18.8.1: Inspections shall be conducted in accordance with the following:

- (a) During erection of ductwork and prior to concealment for the purposes of leakage testing and recording of device location.
- (b) Prior to occupancy and after sufficient completion for the purposes of pressure-difference testing, flow measurements, and detection and control verification.

(4) QUALIFICATIONS. Substitute the following wording for the requirements in IBC section 909.18.8.2: Inspection agencies for smoke control shall have expertise in fire protection engineering, mechanical engineering and certification as air balancers.

(5) REPORTS. Substitute the following wording for the requirements in IBC section 909.18.8.3: A complete report of testing shall be prepared. The report shall include identification of all devices by manufacturer, nameplate data, design values, measured values and identification tag or mark. The report shall be reviewed by the responsible registered design professional and, when satisfied that the design intent has been achieved, the responsible registered design professional shall seal, sign and date the report.

(6) REPORT FILING. Substitute the following wording for the requirements in IBC section 909.18.8.3.1: A copy of the final report shall be maintained and made available to the building official upon request.

(7) SYSTEM ACCEPTANCE. The requirements in IBC section 909.19 are not included as part of this code.