

INSERT PAGES  
IBC CHAPTER 9

To be inserted between pages 196 & 197.

**Comm 62.0910 Smoke and heat vents, and draft curtains. (1) EXCEPTION.**  
Substitute the following wording for exception 1. in IBC section 910.1: Buildings protected by an approved automatic sprinkler system.

**(2) GROUPS F1 AND S1.** Substitute the following wording for the requirements, but not the exception, in IBC section 910.2.1: Buildings and portions thereof used as Group F-1 or S-1 occupancies having more than 50,000 square feet in area that is undivided by full-height walls having smoke resisting characteristics which are similar to those under IBC section 910.3.5.1.