

INSERT PAGES
IEBC CHAPTER 7

To be inserted between pages 28 & 29.

Comm 66.0701 Compliance. This is a department exception to the requirement in IEBC section 701.3: The installation or extension of an automatic sprinkler system may exclude the protection of combustible concealed spaces that are not accessible in existing buildings.