

INSERT PAGES  
IEBC CHAPTER 8

To be inserted between pages 40 & 41.

**Comm 66.0808 Minimum energy conservation requirements.** Substitute the following wording for the requirements in IEBC section 808.1: Level 3 alterations to existing buildings or structures shall comply with s. Comm 66.0607.

**Comm 66.0809 Plumbing.** These are department rules in addition to the requirements in IEBC chapter 8:

(1) Pursuant to s. 101.128, Stats., level 3 alterations within an existing facility where the public congregates shall necessitate that plumbing fixtures serving the work area be provided in a ratio of at least 2 water closets for females as to each water closet and urinal for the males.

(2) (a) Under this section “facility where the public congregates” has the meaning has given in s. 101.128 (1) (b), Stats.

**Note:** Section 101.128 (1) (b), Stats., reads: “Facility where the public congregates” means any of the following that has a general capacity or a seating capacity of 500 or more persons:

1. An amusement facility.
2. A convention or trade hall or center.
3. A specialty event center.
4. A sports or entertainment arena, center or building.
5. A stadium.
6. An airport, bus terminal, train station or other transportation center.

(b) Under this section “alterations” has the meaning has given in s. 101.128 (1) (d), Stats for “renovation”.

**Note:** Section 101.128 (1) (b), Stats., reads: “Renovation” means any structural remodeling, improvement or alteration of an existing facility where the public congregates. “Renovation” does not include any of the following:

1. Reroofing.
2. Cosmetic remodeling, including painting or the installation of wall covering, of paneling, of floor covering or of suspended ceilings.
3. An alteration to an electrical or mechanical system.