

INSERT PAGES  
IEBC CHAPTER 9

To be inserted between pages 46 & 47.

**Comm 66.0901 Change of occupancy.**

**(4) STANDPIPE SYSTEMS.** This is a department rule in addition to the requirements in IEBC section 912.2: Standpipe systems shall be provided in existing buildings and structures or portions of existing buildings and structures in accordance with chapter 9 of the IBC when existing buildings or structures that are greater than 60 feet in height are changed to include a Group R-1 or R-2 occupancy.