

INSERT PAGES
IFGC CHAPTER 3

To be inserted between pages 18 & 19.

Comm 65.0303 Appliance location. (1) GENERAL. This is a department rule in addition to the requirements in IFGC section 303.1: If the air entering the heat exchanger of all gas-fired equipment is 30oF or lower, the heat exchanger and burners shall be constructed of corrosion-resistive materials.

(2) PROHIBITED LOCATIONS. The requirements in IFGC section 303.3 exceptions 3. and 4. are not included as a part of this chapter.