

INSERT PAGES
IFGC CHAPTER 6

To be inserted between pages 120 & 121.

Comm 65.0621 Unvented room heaters. Substitute the following wording for the requirements in IFGC section 621: Portable, gas-fired, unvented heating appliances are prohibited, except during construction or demolition of a building if the appliances are provided in accordance with sh. Comm 14.

Note: See s. Comm 64.0801 (2) for use of portable unvented room heating appliances that are fired with other fuels.